



# **Montour, LLC**

~

## **Ash Area 3**

### **Annual Fugitive Dust Control Report**

**November, 2020**


As required under 40 CFR Part §257.80(c), an Annual CCR Fugitive Dust Control report must be completed for a regulated CCR unit. The initial report is due no later than 14-months after placing the initial CCR fugitive dust control plan in the facility's operating record. The initial Montour Ash Area 3 fugitive dust report was placed in the facility's Facility Operating Record on November 18, 2016. The deadline for subsequent plan completion is 12-months after completion of the previous. The report is considered to be complete after it becomes part of the Facility Operating Record. The annual report is required to contain the following items:

- 1) All actions taken by facility to control fugitive dust generation from Ash Area 3. A copy of the Plan's Weekly Fugitive Dust Inspection Logs are attached to this report – Attachment 1. The weekly inspection logs identify any actions taken to minimize and control fugitive dusting.
- 2) A record of all citizen complains. There were no citizen complaints received during this reporting period associated with the Ash Area 3 CCR unit.
- 3) A summary of any corrective measures taken to mitigate fugitive dust generation. Any corrective action measures taken as a result of identifying fugitive dusting events during the reporting period are included on the Weekly Fugitive Dust Inspection Logs. The logs are included in this report as Attachment 1.

As required under 40 CFR Part §257.106(g), after posting the initial and subsequent Annual CCR Fugitive Dust report to the facility operating record, notification of the posting must be made to the PADEP Regional Waste Director.

This report is also required to be posted to the publicly available web-site as required under 40 CFR Part §257.107(g).

This report was prepared and posted by:

  
Signature / Date

10-29-2020

**Jake McCabe**  
Operations and Maintenance Supt. | Talen Energy  
Office: 570.437.1362  
18 McMichael Rd, Washingtonville PA 17884

# **Attachment 1**

~

## **Weekly Fugitive Dust Inspection Logs**

Attachment A Montour SES - Ash Basin No. 3 Fugitive Dust Inspection Log  
CCR Rule Fugitive Dust Control Plan

DATE (mm/dd/yyyy)	Name of Person Performing Inspection (First Name / Last Name)	Start Time (ex. 0700)	End Time (ex. 0830)	Wind Speed & Direction (ex. 5 mph / SE)	Fugitive Emissions (YES / NO)	Comments/Corrective Actions (if required)	Was Plant Env Professional Notified (YES / NO)
9-16-19	Justin Blocker	1200	1215	5 N	NO		
9-23-19	Justin Blocker	1000	1015	3 E	NO		
9-30-19	Justin Blocker	1020	1035	7 NNE	NO		
10-7-19	Justin Blocker	800	815	8 E	NO		
10-14-19	Justin Blocker	735	810	11 N	NO		
10-21-19	Justin Blocker	1020	1035	6 E	NO		
10-28-19	Justin Blocker	930	945	2 NE	NO		
11-4-19	Justin Blocker	1150	1210	7 NNE	NO		
11-11-19	Justin Blocker	1000	1015	1 E	NO		
11-18-19	Justin Blocker	1100	1115	3 E	NO		
11-25-19	Justin Blocker	930	945	3 S	NO		

NOTE: The Ash Basin No. 1 fugitive dust emissions inspection should include those areas identified in the Ash Basin No. 1 fugitive dust control plan and indicated on the Ash Basin No. 1 Weekly monitoring Program Survey Map. Any "YES" entry in the "Fugitive Emissions" column must include some level of follow-up corrective action measure taken to mitigate the source of the dust emissions. A description of the corrective action measures should be noted in the "Comments / Corrective Actions" column of the form. Any item with a "YES" entry in the "Fugitive Emissions" column must also be reported to the plant environmental professional to determine if agency notification/reporting requirements apply.



**Montour SES - Ash Area No. 3 Fugitive Dust Inspection Log  
CCR Rule Fugitive Dust Control Plan**

DATE (mm/dd/yyyy)	Name of Person Performing Inspection (First Name / Last Name)	Start Time (ex. 0700)	End Time (ex. 0830)	Wind Speed & Direction (ex. 5 mph / SE)	Fugitive Emissions (YES / NO)	Comments/Corrective Actions (if required)	Was Plant Env Professional Notified (YES / NO)
01/06/2020	J. Blocker	925	940	3 E	NO		
01/13/2020	J. Blocker	130	1145	3 NE	NO		
01/20/2020	J. Blocker	1040	1055	9 W	NO		
01/27/2020	J. Blocker	945	1000	12 W	NO		
02/03/2020	J. Blocker	910	925	6 WSW	NO		
02/10/2020	Justin Blocker	1150	1205	7 E	NO		
02/17/2020	J. Blocker	1055	1110	3 WSW	NO		
02/24/2020	J. Blocker	930	945	6 W	NO		
03/02/2020	J. Blocker	1115	1130	5 SSE	NO		
03/09/2020	J. Blocker	950	1005	7 SE	NO		
03/16/2020	J. Blocker	855	910	3 NWS	NO		

**NOTE:** The Ash Area No. 3 fugitive dust emissions inspection should include those areas identified in the Ash Area No. 3 fugitive dust control plan and indicated on the Ash Area No. 3 Weekly monitoring Program Survey Map. Any "YES" entry in the "Fugitive Emissions" column must include some level of follow-up corrective action measure taken to mitigate the source of the dust emissions. A description of the corrective action measures should be noted in the "Comments / Corrective Actions" column of the form. Any item with a "YES" entry in the "Fugitive Emissions" column must also be reported to the plant environmental professional to determine if agency notification/reporting requirements apply.

Montour SES - Ash Area No. 3 Fugitive Dust Inspection Log  
 CCR Rule Fugitive Dust Control Plan

DATE (mm/dd/yyyy)	Name of Person Performing Inspection (First Name / Last Name)	Start Time (ex. 0700)	End Time (ex. 0830)	Wind Speed & Direction (ex. 5 mph / SE)	Fugitive Emissions (YES / NO)	Comments/Corrective Actions (if required)	Was Plant Env Professional Notified (YES / NO)
3/23	Justin Blocker	9:40	9:55	3 NW	NO		
3/30	Justin Blocker	8:45	9:00	9 E	NO		
4/6	Justin Blocker	11:45	12:00	6 NNE	NO		
4/13	Justin Blocker	9:30	9:45	9 SE	NO		
4/20	Justin Blocker	11:45	12:00	N 7	NO		
4/27	Justin Blocker	9:55	10:10	8 NW	NO		
5/4	Justin Blocker	10:25	10:40	9 W	NO		
5/11	Justin Blocker	12:20	12:35	7 WNW	NO		
5/18	Justin Blocker	12:00	12:15	8 SE	NO		
5/25	Justin Blocker	9:25	9:40	7 SE	NO		
6/1	Justin Blocker	9:30	9:45	7 WNW	NO		

NOTE: The Ash Area No. 3 fugitive dust emissions inspection should include those areas identified in the Ash Area No. 3 fugitive dust control plan and indicated on the Ash Area No. 3 Weekly monitoring Program Survey Map. Any "YES" entry in the "Fugitive Emissions" column must include some level of follow-up corrective action measure taken to mitigate the source of the dust emissions. A description of the corrective action measures should be noted in the "Comments / Corrective Actions" column of the form. Any item with a "YES" entry in the "Fugitive Emissions" column must also be reported to the plant environmental professional to determine if agency notification/reporting requirements apply.

Montour SES - Ash Area No. 3 Fugitive Dust Inspection Log  
CCR Rule Fugitive Dust Control Plan

DATE (mm/dd/yyyy)	Name of Person Performing Inspection (First Name / Last Name)	Start Time (ex. 0700)	End Time (ex. 0830)	Wind Speed & Direction (ex. 5 mph / SE)	Fugitive Emissions (YES / NO)	Comments/Corrective Actions (if required)	Was Plant Env Professional Notified (YES / NO)
6/8	Justin Blocker	855	910	7 W	NO		
6/15	Justin Blocker	1105	1120	3 var	NO		
6/22	Justin Blocker	1030	1045	6 SE	NO		
6/29	Justin Blocker	1140	1155	9 NW	NO		
7/6	Justin Blocker	925	940	10 E	NO		
7/13	Justin Blocker	920	945	6 SSW	NO		
7/20	Justin Blocker	850	905	8 W	NO		
7/27	Justin Blocker	1030	1045	5 SW	NO		
8/3	Justin Blocker	1020	1035	9 WNW	NO		
8/10	Justin Blocker	1140	1155	3 W	NO		
8/17	Justin Blocker	1225	1240	7 SW	NO		

NOTE: The Ash Area No. 3 fugitive dust emissions inspection should include those areas identified in the Ash Area No. 3 fugitive dust control plan and indicated on the Ash Area No. 3 Weekly monitoring Program Survey Map. Any "YES" entry in the "Fugitive Emissions" column must include some level of follow-up corrective action measure taken to mitigate the source of the dust emissions. A description of the corrective action measures should be noted in the "Comments / Corrective Actions" column of the form. Any item with a "YES" entry in the "Fugitive Emissions" column must also be reported to the plant environmental professional to determine if agency notification/reporting requirements apply.



Montour SES - Ash Area No. 3 Fugitive Dust Inspection Log  
 CCR Rule Fugitive Dust Control Plan

DATE (mm/dd/yyyy)	Name of Person Performing Inspection (First Name / Last Name)	Start Time (ex. 0700)	End Time (ex. 0830)	Wind Speed & Direction (ex. 5 mph / SE)	Fugitive Emissions (YES / NO)	Comments/Corrective Actions (if required)	Was Plant Env Professional Notified (YES / NO)
8/24/20	J. Block	9:55	10:10	SWSW	NO		
8/31/20	J. Block	10:00	10:15	43E	NO		
9/17/20	J. Block	10:15	10:30	ENE 6	NO		
9/14/20	J. Block	9:25	9:40	6W	NO		
9/21/20	J. Block	12:25	12:40	3SE	NO		
9-28-20	J. Block	8:00	8:15	6W	NO		
10-5-20	J. Block	10:00	10:15	107	NO		
10/12/20	J. Block	9:35	9:50	7E	NO		
10/19/20	J. Block	10:00	10:15	8E	NO		
10/26/20	J. Block	10:25	10:40	5E	NO		

NOTE: The Ash Area No. 3 fugitive dust emissions inspection should include those areas identified in the Ash Area No. 3 fugitive dust control plan and indicated on the Ash Area No. 3 Weekly monitoring Program Survey Map. Any "YES" entry in the "Fugitive Emissions" column must include some level of follow-up corrective action measure taken to mitigate the source of the dust emissions. A description of the corrective action measures should be noted in the "Comments / Corrective Actions" column of the form. Any item with a "YES" entry in the "Fugitive Emissions" column must also be reported to the plant environmental professional to determine if agency notification/reporting requirements apply.