



*Prepared for:*

Talen Energy  
835 Hamilton St., Suite 150  
Allentown, PA 18101

# **RUN-ON AND RUN-OFF CONTROL SYSTEM PLAN**

**Per Requirements of 40 CFR §257.81**

**Montour SES Ash Landfill 3  
Washingtonville, Pennsylvania**

*Prepared by:*

**Geosyntec**   
consultants

10211 Wincopin Circle, Floor 4  
Columbia, Maryland 21044

Project Number ME1207A

October 2016

Periodic Update October 2021

## TABLE OF CONTENTS

1.	INTRODUCTION .....	1
1.1	Organization and Terms of Reference .....	1
1.2	Site Location .....	1
1.3	Landfill Description .....	1
1.4	2021 Periodic Update .....	2
2.	CCR RULE REQUIREMENTS FOR RUN-ON/ RUN-OFF CONTROLS (§257.81)...	3
2.1	Run-On and Run-Off Control Requirements for CCR Landfills (§257.81) .....	3
2.2	Compliance with Run-On and Run-Off Controls Requirements .....	3
3.	RUN-ON AND RUN-OFF CONTROL SYSTEM PLAN .....	5
3.1	Introduction .....	5
3.2	Description of Run-On and Run-Off Controls Design and Construction .....	5
3.3	Identification of the Design Storm .....	6
3.4	Characterization of Rainfall Abstractions .....	6
3.5	Selection and Basis of Run-Off Model .....	6
3.6	Selection and Basis of Run-On and Run-Off Routing Model .....	7
3.7	Selection and Design of Run-on and Run-Off Management System .....	7
3.8	Supporting Engineering Calculations .....	7
4.	CERTIFICATION BY QUALIFIED PROFESSIONAL ENGINEER .....	8
5.	REFERENCES .....	9

## LIST OF FIGURES

Figure 1 – Location map

## LIST OF APPENDICES

Appendix A – Drawings

Appendix B – Design Concept and Operating Plan (Attachment 1 to Form 1R of PPL 2007)

Appendix C – Design Calculations (Attachment 1 to Form I of PPL 2007)

## 1. INTRODUCTION

### 1.1 Organization and Terms of Reference

Geosyntec Consultants (Geosyntec) has prepared this Run-on and Run-off Control Systems Plan for Talen Generation, LLC (Talen) to demonstrate compliance of the existing Montour SES Ash Landfill 3 (Ash Landfill 3) in Washingtonville, Pennsylvania with the operating criteria of the Federal Coal Combustion Residuals (CCR) Rule. On 17 April 2015, the USEPA published the final rule for disposal of CCR from electric power utilities under Subtitle D of the Resource Conservation and Recovery Act (RCRA), contained in Section 257 of Title 40 of the Code of Federal Regulations (40 CFR 257 Subpart D), referred to here as the CCR Rule. Section 257.81 contains the requirements for run-on and run-off controls of CCR landfills. In this Run-on and Run-off Control System Plan, the specific requirements of §257.81 are identified and addressed.

The initial Run-on and Run-off Control Systems Plan was prepared by Mr. Michael Nolden, and it was reviewed in accordance with Geosyntec's internal review policy by Mr. Michael Houlihan, P.E. and Mr. Thomas Ramsey, P.E., all of Geosyntec. Mr. Ramsey, a registered Professional Engineer in the Commonwealth of Pennsylvania, certified the initial plan.

The 2021 periodic update to this Run-on and Run-off Control System Plan was prepared by Mr. Michael Nolden, P.E., and it was reviewed in accordance with Geosyntec's internal review policy by Mr. Michael Houlihan, both of Geosyntec. Mr. Nolden is a registered Professional Engineer in the Commonwealth of Pennsylvania.

### 1.2 Site Location

Montour SES is located in Washingtonville, Montour County, Pennsylvania. The site can be found on a United State Geological Survey 7.5-minute topographic map for the Washingtonville Quadrangle (Figure 1). Ash Landfill 3 is located within the Montour SES site, southeast of the generating station.

### 1.3 Landfill Description

Ash Landfill 3, also called Ash Area 3 or Ash Storage Area 3, is a CCR landfill constructed in 1990 to accept coal combustion residuals produced by the Montour SES, as described by Form R of the Pennsylvania Department of Environmental Protection (PADEP) Class II Residual Waste Disposal Facility permit renewal (PADEP Permit) application package (PPL 2007). Ash Landfill 3 has been in service since 1991 (PPL 2007, Attachment 1 to Form 1R).

Ash Landfill 3 is regulated under the Pennsylvania Residual Waste Regulations of Title 25 PA Code, Chapters 287 and 288. The unit is permitted as a PADEP Residual Waste Disposal Facility. Ash Landfill 3 was constructed and is operated under a renewal of Permit No. 300987 for a Landfill—Class I, II, or III (PADEP 2007), which was issued in August 2007.

Ash Landfill 3 was designed as a two-phase landfill with each phase comprising three levels, as shown on drawing E-195972-3 in Appendix A. At the time of the 2021 periodic update,

landfilling operations have only been performed in Phase I. The portion of the permit area designated for Phase II remains undeveloped.

#### **1.4 2021 Periodic Update**

In accordance with the requirements of §257.81(c)(4) of the CCR Rule, Geosyntec performed a periodic update to this Run-on and Run-off Control System Plan in October 2021. The approach for the update was as follows:

- Verify the current provisions of the CCR rule regarding run-on and run-off control systems;
- Perform a site visit to evaluate current site conditions and run-on and run-off controls and management practices; and
- Review the information in this plan for correctness and accuracy relative to the conditions observed during the site visit.

The periodic update was prepared based on the following:

- the initial Run-on and Run-off Control System Plan, dated October 2021, prepared by Geosyntec Consultants.
- current topographic surveys of Ash Landfill 3 performed by Borton-Lawson of Wilkes-Barre, Pennsylvania on 17 May 2021 and provided electronically to Talen on 22 June 2021 (Borton-Lawson 2021);
- observations made by Michael Nolden, P.E., during a 2 August 2021 site visit; and
- personal communications with Talen personnel.

Based on the outcomes of the above tasks, Geosyntec found that Ash Landfill 3, at the time of the reparation of this periodic update, was operated in accordance with the provisions of the initial Run-on and Run-off Control System Plan. Also, an update to the text of Section 3.2 of this report (i.e., Description of Run-On and Run-Off Control System Design and Construction) was made to reflect current conditions.



## **2. CCR RULE REQUIREMENTS FOR RUN-ON/ RUN-OFF CONTROLS (§257.81)**

### **2.1 Run-On and Run-Off Control Requirements for CCR Landfills (§257.81)**

As described in §257.81, an existing CCR landfill must design, construct, operate, and maintain run-on/run-off controls to prevent flow onto and from active cells from a 24-hr, 25-yr storm event. The rule requires that the CCR landfill be designed, constructed, operated, and maintained to collect and control at least the water volume resulting from a 24-hour, 25-year storm (§257.81(a)). Additionally, the CCR landfill must comply with 40CFR§257.3-3 which regulates discharge of pollutants into the waters of the United States (§257.81(b)). Section 257.81(c) of the rule requires that the owner or operator of a CCR landfill prepare an initial run-on and run-off control system plan documenting, with supporting engineering calculations, how the control systems have been designed and constructed to meet the requirements of §257.81(a). Pages 21389-21390 of the Preamble to the CCR rule describe the type of documentation that is expected to be included in the Run-On and Run-Off Control System Plan.

### **2.2 Compliance with Run-On and Run-Off Controls Requirements**

Part 3 of this document presents the demonstration of compliance with the requirements of §257.81. Section 257.81(a) addresses the performance requirement of the run-on and run-off control system, which is satisfied by the identification of the design storm in Section 3.3. The requirement of §257.81(b), which addresses the handling requirements of run-off collected from the landfill, is satisfied by and monitored under the facility's National Pollutant Discharge Elimination System (NPDES) permit program.

The specific documentation that is expected to be provided in the Run-on and Run-Off Control System Plan is described in the Preamble at pages 21389-21390. The table below summarizes the minimum CCR Rule requirements for a run-on and run-off control system plan from §257.81(c) and the Preamble, and the location in this document where those requirements are addressed.

RULE SECTION	RULE REQUIREMENT	LOCATION WHERE ADDRESSED IN DOCUMENT
§257.81(c)(1)	Owner or operator must prepare initial and periodic run-on and run-off control system plans for the unit	Part 3
	Document how the run-on and run-off controls have been designed and constructed.	Section 3.2
Preamble Pages 21389-21390	Identification of 24-hr, 25-yr Storm	Section 3.3
	Characterization of Rainfall Abstractions	Section 3.4
	Selection and Basis of Run-Off Model	Section 3.5
	Selection and Basis of Run-On and Run-Off Routing Model	Section 3.6
	Selection and design Run-On and Run-Off Management System	Section 3.7
	Supporting Engineering Calculations.	Section 3.8
§257.81(c)(5)	Written Certification from qualified professional engineer that initial Run-On and Run-Off Control System Plan meets the requirements of §257.81(c).	Section 4

### 3. RUN-ON AND RUN-OFF CONTROL SYSTEM PLAN

#### 3.1 Introduction

The information presented in the following sections demonstrates the Montour SES Ash Landfill 3 is in compliance with the run-on and run-off control system with the requirements of the CCR Rule §257.81(c)(1) and preamble.

The CCR Rule (preamble Page 21389) defines *run-on* to mean any liquid that drains overland onto any part of a CCR landfill. Conversely, the CCR Rule defines *run-off* to mean any liquid that drains overland from any part of the CCR landfill.

#### 3.2 Description of Run-On and Run-Off Controls Design and Construction

The design for the Run-On and Run-Off Control System for Ash Landfill 3 is provided in the approved Erosion and Sedimentation Control Plan (PPL 2007, Attachment 1 to Form I) and the unit's Design Concept and Operating Plan document (PPL 2007, Attachment 1 to Form 1R) (Appendix B). The design and construction of these controls are described below.

##### *Design of Run-On and Run-Off Controls*

The location of Ash landfill 3 is such that overland flow of stormwater run-on is intercepted by a bordering tributary or by a perimeter access road and diverted to culverts west of Phase I of Ash Landfill 3 (Attachment 1 to Form I).

Run-off from Ash Landfill 3 will be handled in one of two ways (Attachment 1 to Form I):

- Run-off from active or unvegetated portions of the landfill will be directed to the leachate basin for treatment and discharge
- Run-off from vegetated or covered portions of the landfill will be directly to perimeter drainage ditches for discharge to the tributary.

A dirty run-off ditch, constructed first, intercepts dirty runoff from active portions of the landfill and conveys the run-off as described above (Attachment 1 to Form 1R). Once a portion of the landfill is vegetated, a clean run-off ditch is constructed between the landfill slope and the dirty run-off ditch (Attachment 1 to Form 1R). As the landfill expands vertically, bench ditches are constructed to intercept flow down the side slopes and discharge it to one of the appropriate ditch (i.e., either clean or dirty) through slope pipes.

Plan and details of the run-off control system, as designed, is shown on the following drawings in Appendix A:

- E-195969 (Sheets 1, 2, and 3)
- E-195970 (Sheets 1 and 2)
- E-195971
- E-195972

At the time of the 2021 periodic update, runoff from the north slope and east slope north of the access road is managed as described above for clean run-off. All other run-off is directed by a series of dirty run-off ditches and slope pipes to the leachate basin for treatment.

### *Construction of Run-On and Run-Off Controls*

The dirty run-off ditches were constructed and, where appropriate, are in the process of being converted to clean run-off ditches once all of the stormwater controls are in place and design elevation of waste materials are achieved. All stormwater is collected in the dirty run-off ditches and routed to the leachate basin for treatment and discharge (Benjamin Wilburn, personal communication, 30 November 2015).

No additional as-built or construction documentation was located to verify that the run-on and run-off controls were constructed per the design.

Specific requirements for the Run-On and Run-Off Control Systems Plan, as outlined by the CCR Rule preamble (Pages 21389 and 21390), are identified and addressed below.

### **3.3 Identification of the Design Storm**

The identification of the design storm is not explicitly described in the available documentation. The introduction to Attachment 1 to Form I of PPL (2007) states that the original stormwater calculations have been verified to show that that run-on and run-off control system can accommodate a 24-hour, 25-year storm event.

Stormwater run-off calculation appended to Attachment 1 to Form I show that the original design storm was selected to be a 24-hour, 10-year storm and that the calculations were revised to consider a 24-hour, 25-year storm. The calculations show that a rainfall intensity of 5.0 inches per hour was selected for design.

### **3.4 Characterization of Rainfall Abstractions**

Stormwater run-off calculations appended to Attachment 1 to Form I show that rainfall abstractions are characterized by a runoff curve number (CN). The calculations show that CN used was a weighted CN based on the post-development conditions of Ash landfill 3 and the adjacent features (e.g., access roads and run-off ditches).

### **3.5 Selection and Basis of Run-Off Model**

The calculations appended to Attachment 1 to Form 1R show that the calculations were performed based on methods presented in the Soil Conservation Service (SCS). The calculations show that the peak discharges were calculated from figures published by SCS for the calculation of peak rates of discharge for small watersheds. The calculations show that additional hydrologic information such as hydrographs, CN, and times of concentration were calculated using HydroCAD software Quick TR-55.

### **3.6 Selection and Basis of Run-On and Run-Off Routing Model**

The selection and basis of the run-on and run-off routing model was not identified in the documentation reviewed.

### **3.7 Selection and Design of Run-on and Run-Off Management System**

Design of the run-on and run-off management system is shown in Calculations appended to Attachment 1 to Form I. The calculations show that the ditches were analyzed and designed as trapezoidal open channels using software developed by Haestad Methods Inc.

### **3.8 Supporting Engineering Calculations**

Engineering calculations supporting the design of the run-on and run-off controls at Ash Landfill 3 are appended to Attachment 1 to Form I of PPL (2007) (Appendix C).

#### 4. Certification by Qualified Professional Engineer

Per §257.81(c)(5), the owner or operator of the unit must obtain a written certification from a qualified professional engineer that the run-on and run-off control system plan meets the requirements of the CCR Rule.

##### Certification for Run-On and Run-Off Control System Plan

CCR Unit: Montour SES Ash Landfill 3


##### Certification

I, **Michael Nolden**, a registered professional engineer in the Commonwealth of Pennsylvania certify that the Run-On and Run-Off Control System Plan for the Montour SES Ash Landfill 3 is in compliance with requirements of 40 CFR §257.81(c). This certification is based on my review of information described in this certification report.

Printed Name Michael Nolden

PE License Number PE087034

State Pennsylvania

Signature 

Date 7 October 2021

Seal




## 5. REFERENCES

- Borton-Lawson (2021). “VX-CONT-Montour\_Area 3\_PLANT\_20210517.” Electronic survey file. Borton-Lawson, May 2021.
- PADEP (2007). “Permit for Solid Waste Disposal and/or Processing Facility FORM NO. 8.” Pennsylvania Department of Environmental Protection, Bureau of Land Recycling and Waste Management. August 2007.
- PPL (2007). “PPL Montour, LLC – Ash Area #3 Permit Renewal Application – SWP 300987.” PPL Services Corporation. Allentown, PA. March 2007.
- United States Environmental Protection Agency (USEPA) (2015). “Hazardous and Solid Waste Management System; Disposal of Coal Combustion Residuals from Electric Utilities; Final Rule.” Chapter 40 Code of Federal Regulations, Parts 257 and 261. 17 April 2015.

## FIGURES





Produced by the United States Geological Survey

North American Datum of 1983 (NAD83)  
World Geodetic System of 1984 (WGS84) Projection and  
100-meter grid. National Topographic Map, Zone 18  
18 000 000 000. Pennsylvania Coordinate System of 1983  
(PAC83)

Imagery: NAD, July 2010  
Base: 2010-2011, Topo  
Hydrography: NAD, 2010  
Contours: National Elevation Dataset, 2010  
Boundaries: Census, 2010, USGS, 1970-2010



SCALE 1:24 000  
Kilometers  
Meters  
Feet  
COUNTRY INTERVAL 20 FEET  
NORTH AMERICAN DATUM OF 1983  
This map was produced in conformance with the  
National Geospatial Program US Topo Product Standard, 2011.  
A resolution file associated with this product is available at version 5.0.1.1



ROAD CLASSIFICATION  
Expressway  
Secondary Hwy  
Ramp  
Interstate Route  
Local Connector  
Local Road  
4WD  
US Route  
State Route

WASHINGTONVILLE, PA  
2013

SITE LOCATION  
MONTOUR SES

WASHINGTONVILLE, PA

Geosyntec  
consultants

FIGURE

1

Columbia, MD

12 April 2016

## **APPENDIX A**

### Drawings
























PLAN - PHASE II  
CELL DEVELOPMENT - LEVEL III  
SCALE: 1"=100'

NOTE:  
1. WORK THIS DRAWING WITH DRAWING E-195965 - CONSTRUCTION DEVELOPMENT - SEQUENCE PLANS.  
2. TIE SLOPE PIPE INTO "DIRTY" RUNOFF DITCH UNTIL ALL RUNOFF IN PIPE IS FROM VEGETATED AREAS - THEN TIE INTO CLEAN RUNOFF DITCH. (TYPICAL ALL SLOPE PIPES)



SECTION 9-9  
LEVEL III BENCH DETAIL  
NO SCALE



SECTION 10-10  
NO SCALE

- LEGEND**
- EL. 588.50 FINISHED GRADE SPOT ELEVATION
  - 588 — FINISHED GRADE CONTOUR
  - EXISTING CLEAN RUNOFF DITCH
  - EXISTING DIRTY RUNOFF DITCH
  - NEW DIRTY RUNOFF DITCH
  - NEW CLEAN RUNOFF DITCH
  - x EL. 563.45 EXISTING GRADE SPOT ELEVATION

REFERENCE TITLE	NUMBER	REFERENCE TITLE	NUMBER	NO.	DATE	BY	CH.	APPROVED	NO.	DATE	BY	CH.	APPROVED	NO.	DATE	BY	CH.	APPROVED	NO.	DATE	BY	CH.	APPROVED
INTERMEDIATE DEVELOPMENT - PHASE I	E-195969	INTERMEDIATE DEVELOPMENT - PHASE II	E-195970	1	6-8-88	108069																	
BILL OF MATERIAL	A-1088980																						

WORK THIS DRAWING WITH E-195965

U.S. 045155-000  
ER-480230  
ER-  
SCALE: AS NOTED  
DATE: 1-19-84  
DRAWN: TEC


CHECKED: FAC  
LEADER: A.L.M.  
APPROD: W.B.  
APPROD:

PENNSYLVANIA POWER & LIGHT COMPANY  
ALLENTOWN, PA.

APPROVED  
1/24/84 John A. Stetford

E-195971-3





WORK THIS DRAWING WITH E-195963

#. 045155-000

ER-480230

ER-

ASH DISPOSAL AREA NO.2

SCALE: AS NOTED

DATE: 1-15-84

DRAWN: T.E.C.

MONTOUR S.E.S.

INTERMEDIATE CELL DEVELOPMENT - SLOPE PIPE  
SECTIONS AND DETAILS

**PENNSYLVANIA POWER & LIGHT COMPANY**  
ALLENTOWN, PA.

CHECKED: FAC  
LEADER: A.L.W.  
APPD: WJB  
APPROV:

APPROVED  
1/16/84 John P. Steffani

E-195972-

## **APPENDIX B**

Design Concept and Operating Plan

(Attachment 1 to Form 1R of PPL 2007)

SPECIFICATION PPC-2006  
DESIGN CONCEPT AND OPERATING PLAN  
FOR ASH DISPOSAL AREA NO. 3

MONTOUR STEAM ELECTRIC STATION  
ASH DISPOSAL AREA NO. 3  
ER 103069

PENNSYLVANIA POWER & LIGHT COMPANY  
POWER PLANT ADDITIONS ENGINEERING  
JANUARY 27, 1984

APPROVED: John A. Stefanik  
Responsible Engineer

Revised for Permit Renewal Application  
Revised per DEP Comments  
Revised for Residual Waste Permit Minor Modification  
Revised for Residual Waste Permit Minor Modification  
Revised for Residual Waste Permit Minor Modification  
Revised for Application for Residual Waste Disposal Permit Modification

Revision 11 - 3/20/07  
Revision 10 - 9/12/06  
Revision 9 - 3/27/06  
Revision 8 - 7/08/04  
Revision 7 - 3/31/04  
Revision 6 - 2/8/99  
Revision 5 - 4/22/97  
Revision 4 - 6/10/96  
Revision 3 - 9/26/86  
Revision 2 - 4/30/86  
Revision 1 - 5/28/85

## TABLE OF CONTENTS

	<u>Page</u>
General Operational Concept for Proposed Facility .....	1
Design Concept .....	1
Site Development .....	1
Drainage Blanket and Leachate Underdrain System (Leachate Collection System) .....	2
Type of Liner System.....	2
Leachate/Runoff Basin .....	3
Storm Water Handling .....	4
Borrow Areas.....	5
Site Roadways and Access Control .....	5
Grid Markers.....	5
Buildings and Other Structures .....	5
Utilities.....	6
Construction Sequence Plan .....	6
Waste Type and Quantity .....	7
Waste Type and Origin.....	7
Waste Composition .....	8
Waste Quantities .....	9
Proposed Capacity of Landfill .....	9
Expected Life of Facility .....	10
Waste Disposal Operations .....	10
Operating Plan .....	10
Sequence and Timing of Solid Waste Disposal Operations.....	13
Disposal Operation Equipment .....	13
Erosion and Sedimentation Control .....	14
Dust Control .....	14
Litter Control.....	15
Traffic Control.....	15
Safety .....	16
Records .....	16
Communications .....	16
Employee Training Program .....	17
Post-Closure Use of Land and Structures and Site Maintenance.....	17



MONTOUR STEAM ELECTRIC STATION  
ASH DISPOSAL AREA NO. 3  
DESIGN CONCEPT AND OPERATING PLAN

General Operational Concept

Ash Disposal Area No. 3 is an existing captive residual waste disposal facility owned and operated by PPL Montour, LLC. The landfill serves Montour Steam Electric Station, a coal fired electrical generating station located in Derry Township, Montour County Pennsylvania. Ash Area No. 3 went into operation in 1991 to replace Ash Area No. 2 that was filled to capacity. Ash Area No. 3 is a lined landfill that is used primarily for the disposal of fly ash and other coal combustion products generated from burning coal at the plant. Smaller quantities of other plant residual wastes are also approved for disposal in Ash Area 3

Fly ash is collected from the station's electrostatic precipitators and pneumatically conveyed in an above-ground pipeline to two steel storage silos located approximately 3,000 feet to the southeast of the plant site. From the storage silos the fly ash is either removed dry or amended with hydrated lime for beneficial use as stabilized product or for mine reclamation. It is PPL's intent to beneficially use as much ash as possible thereby minimizing the amount that needs to be disposed. Fly ash that is not beneficially used is moistened and trucked to the disposal area, end-dumped and then spread and compacted. Other approved wastes sent to the disposal facility are handled in a similar manner trucked, end-dumped, spread and compacted in the landfill.

Up to 54,000 tons of synthetic gypsum, a co-product of stack gas scrubber operation, may be temporarily stored on-site on Level 2 of the landfill until it can be transported off-site for mine reclamation as defined under a PA General Beneficial Use Permit and other beneficial uses authorized under 25 PA Code Chapter 287. The 54,000 tons represents approximately 15 days of the annual gypsum production total, and will consist of non-conforming material not acceptable as a raw product for wallboard manufacturing.

PPL also plans to dispose of wastewater treatment plant sludge beginning in 2008 after the stack gas scrubber operation begins. At full load capacity it is expected that up 100 tons per day of sludge would be disposed of in Ash Area No.3. The sludge will be a mixture of calcium sulfate solids and precipitated heavy metals from the water treatment plant process.

Design Concept

Site Development

The boundaries of the disposal area were determined by topographic features and structures such as roads and transmission lines. The site is divided into eastern and western segments by a small stream that flows across the site. This stream is now carried in twin four-foot diameter pipes that were installed as part of the site development. These pipes were designed to handle the runoff from a 100-year/24-hour storm event.

The disposal area will have three levels each approximately 25 feet in height with three horizontal to one vertical side slopes. Each level will have a 20-foot-wide bench. The first level covers 50.6 acres and will be divided into four disposal cells of approximately the same size. The A and B disposal cells totaling 28.9 acres are on the east side of the stream enclosure

pipes and the C and D disposal cells totaling 21.7 acres are on the west side. At this time only the A and B cells have been developed and used for disposal. The C and D cells will not be developed until the A and B cells have reached their design capacity.

Topsoil is stripped from each cell prior to preparing the subgrade and constructing the liner system. Stripped topsoil is stockpiled at the site for later use in covering the ash pile.

#### Drainage Blanket and Leachate Underdrain System (Leachate Collection System)

A drainage blanket and leachate underdrain system was constructed at the base of the landfill to collect and remove any water that may enter the pile and reduce its stability. This water comes from rainwater that has infiltrated the pile. The drainage blanket consists of a pervious, compacted layer of bottom ash having a depth of two feet. The underdrain system consists of a network of perforated pipe. The underdrain system discharges directly into the Leachate/Runoff Basin sump. A geotextile filter fabric was placed over the bottom ash to prevent the fly ash from entering and clogging the drainage blanket and underdrain system.

#### Type of Liner System

Solid and liquid wastes are prevented from contacting the site ground water through the use of impervious liners. A polyvinyl chloride (PVC) geomembrane 30 mils in thickness is placed under the landfill as the cells are developed. The geomembrane is placed over a six-inch layer of bottom ash sand. The sand provides a base free from rocks, rubble and other debris that could puncture the geomembrane. Upon completion of the geomembrane installation, all seams are tested to ensure that they are properly bonded. The geomembrane is protected on the top by a geotextile 110 mils thick. This geotextile protects the PVC geomembrane from being abraded or punctured during placement of the drainage blanket material.

To maintain a minimum four-foot separation between the bottom of the liner and the seasonal high ground water table, a system of stone filled drains and collector pipes was installed to artificially dewater the site by gravity drainage. This system discharges to a small unnamed tributary of Mud Creek that drains the site. Fill was used in selected areas to maintain the required separation where it was not provided by the drains alone. Based on a detailed study of the acid producing potential of the subsurface materials at the site which might be exposed to oxidation as a result of excavating the drains, the discharge from the site dewatering systems does not require treatment.

Additional protection against seepage into ground water is provided by the site soils that are fine grained silt-clay soils. These soils have an in-place permeability ranging from  $2 \times 10^{-6}$  to  $1 \times 10^{-8}$  cm/sec. The soils vary in thickness from one and one-half feet to six feet. The soils serve as a secondary liner system.

Dirty runoff ditches are lined with concrete or clay. The dirty runoff ditch along the south side of the ash pile was lined with concrete. The ditch in this section receives most of the runoff from the ash pile. Concrete provides the erosion resistance and impermeability required of a liner. It also allows the ditch to be cleaned of fly ash sediment without damaging the integrity of the liner. In most areas the ditches are cut in impervious soils. If they were cut in rock, they were over-excavated and lined with one foot of clay.



### Leachate/Runoff Basin

A Leachate/Runoff Basin approximately three acres in size was constructed for the disposal area. All runoff from the active A and B cells, and from intermediate construction activities is directed to the basin for sediment removal as will be construction runoff from the future C and D cells when developed. All leachate collected in the underdrain system is also directed to the basin, but into the basin sump. The Leachate/Runoff Basin has a double liner. A polyvinyl chloride (PVC) geomembrane 30 mils in thickness is the primary liner. It is covered with the silt-clay soils at the site to form a soil liner with a permeability of  $1 \times 10^{-7}$  cm/sec or less. The soil liner has a minimum thickness of one foot.

The Leachate/Runoff Basin is divided into two sections. The larger portion is designed primarily for sediment removal and control of storm water flows. The smaller section contains the pumping station and sump into which the larger section discharges. A ramp permits excavating equipment to enter the larger section and remove any accumulations of fly ash sediment. The sediment removed from the basin is re-deposited on the ash pile. Runoff and leachate that have entered the Leachate/Runoff Basin is pumped to the Detention Basin at the power plant for treatment in existing wastewater treatment facilities.

Because of the high groundwater table, the Leachate/Runoff Basin has been provided with an underdrain system to draw down the groundwater to below the bottom of the basin. This system consists of a stone drainage blanket with six-inch diameter drainage tubing draining by gravity to the natural stream to the south of the disposal area.

During normal conditions, when the underdrain system is free flowing, there is no uplift pressure on the geomembrane liner because the groundwater is kept below it. During flood events, the groundwater underdrain outlet is submerged by the floodwaters, and the groundwater may rise and exert an upward pressure on the geomembrane. A one-foot depth of water will be maintained in the basin at its lowest point, the polishing pond section, to provide stability (no net uplift pressure) for all flood events up to and including the 100-year flood. The stability calculations did not take advantage of the head provided by storm runoff that would enter the basin.

Hydrologic calculations show that the duration of flood flows for the various frequency events are on the order of six to eight hours. It would take approximately 22 hours to pump the runoff from the two-year frequency storm out of the Leachate/Runoff Basin and 72 hours to pump the runoff from the 100-year storm. This indicates that there will be water in the pond for a lengthy period after the flood waters peak. This head provides additional assurance that there will not be a net uplift on the geomembrane. It also provides time for the underdrain system to draw down the water table to the before-flood elevations.

The Leachate/Runoff Basin slopes are 3 horizontal to 1 vertical. They are stable under both dry and saturated conditions.

## Storm Water Handling

To reduce storm water handling requirements, runoff is segregated into "clean" runoff and "dirty" runoff. Clean runoff is runoff from undisturbed areas and from disturbed areas that have been covered with topsoil and revegetated. Dirty runoff is runoff from unvegetated areas (including the stripped subgrade during construction), from the active ash cells on the ash disposal pile, and from inactive cells that have been covered with topsoil and seeded, but on which the vegetation has not yet been established.

Clean and dirty runoff ditches are constructed in parallel around the disposal pile (except between perimeter access road stations 40+00 and 63+00). The dirty runoff ditch is constructed first and intercepts dirty runoff from the ash pile and conveys it to the Leachate/Runoff Basin for treatment. After vegetation has been established on the completed ash cells, a clean runoff ditch is constructed between the pile and the dirty runoff ditch. This ditch intercepts the clean runoff before it enters the dirty runoff ditch and diverts it around the Leachate/Runoff Basin to the natural stream at the south end of the site.

Between perimeter access road stations 40+00 and 63+00, the dirty runoff ditch will be cleaned and then converted to a clean runoff ditch. Clean runoff will be discharged beneath the access road to the inlet end of the stream enclosure. Dirty runoff from the top of the pile will be directed to the south. The working surface of active cells will be sloped at approximately one percent towards dirty runoff ditches at the south end of the ash pile. This will minimize erosion of the ash slopes. Any slope erosion that may occur will be remedied prior to covering with topsoil and seeding. Straw bales will be placed at the toe of the ash pile slopes to prevent excessive sedimentation of the dirty runoff ditch and the runoff basin.

When a cell reaches its 25-foot height, the permanent bench and bench drainage ditch is established by sloping the outer 20 feet of the ash cell away from the edge. The bench and ditch are then covered with shale or some other non-erodable material. The bench drainage ditch intercepts runoff from the top of the pile preventing further erosion of the ash slopes. The outside slopes of the completed cell are then covered with topsoil and seeded. Discharge from the bench drainage ditches is through slope pipes which discharge into either the clean or dirty runoff ditches, as applicable, at the base of the pile. Runoff is considered to be dirty until vegetation is established on the slopes of the cell on the above level. Slope pipes will discharge on concrete splash pads to prevent scouring of the ditch.

The Leachate/Runoff Basin was originally sized to handle the runoff from a 24-hour rainfall of 10-year frequency. The new Residual Waste Management Regulations require that it be designed for the 24-hour rainfall of 25-year frequency. There should be no discharge to the natural stream near the landfill for rainfalls up to this magnitude.

The existing Ash Area 3 storm water handling system design played a major factor in the decision to locate the temporary synthetic gypsum storage pile on top of Level 2. Storm water runoff from the gypsum pile will be handled by the existing dirty runoff conveyance system. Fabric filter silt fence will be placed around the temporary storage piles to contain any gypsum mobilized during storm events. Storm water runoff will enter the existing storm water channels and be conveyed to the Leachate/Runoff Basin. This will eliminate any solids deposition in streams and natural drainage channels outside of the landfill. No additional storm water controls are required to accommodate temporary synthetic gypsum storage.



### Borrow Areas

A soil borrow area has been developed on nearby property west of the site to provide soil for final cover and other construction purposes when there is a deficit of suitable on-site soils. The first probable use of the borrow area will be to provide cover soil for side slopes and the top of Level 3 of the A and B cells. When and if construction of the C and D cells is needed, fill material will also be required to bring the subgrade to design elevation. The borrow area will also be the source of some of the final cover material for the C and D cells.

### Site Roadways and Access Control

The existing access road from highway LR 414 (PA 876) to the ash storage silo area is an asphalt-paved roadway 20 feet in width. The haul road from the silo area to the Area No. 3 landfill and the leachate/runoff basin is also paved. The haul road is now complete adjacent to the A and B cells and will loop around the entire landfill when the C and D cells are constructed. The road is 22 feet in width and asphalt-paved except for the segment on the west side of the C and D cells. That segment will be a gravel-surfaced road since it will not be used for daily hauling operations but for maintenance access. The road will be approximately 6,900 feet long at completion of which 5,300 feet will be paved and about 1,600 feet will be gravel-surfaced.

The silo area is fenced and gated to prevent access from public highway LR 414. Access to the landfill and leachate/runoff collection basin from the silo area is also controlled via a gate in the silo area fence on the west side. The temporary ends of the loop road around the landfill have also been gated. All gates are padlocked to prevent unauthorized access when the site is unattended.

### Grid Markers

Although the loop roadway clearly defines the limits of waste disposal, grid markers and benchmarks have been installed at the landfill. The markers are located near the corners of the loop road and near the ends of the stream enclosure. The markers are labeled with the Montour plant (local) grid coordinates and the elevation of the benchmark based on USGS datum. The grid markers and benchmarks are used to control waste placement and to control facility construction activities.

### Buildings and Other Structures

The silos, administration building, maintenance buildings and other facilities needed to support the operation of Ash Area No. 3 existed at the time the landfill was constructed. Located at the ash silo area to the east of the landfill are two 2,500 ton capacity steel silos that store the fly ash until it is unloaded for beneficial use or disposal. Located near the silos are two buildings. The 62 foot x 42 foot building adjacent to the silos, houses the silo auxiliary equipment and silo electrical switchgear. Across the road from this building is the 142 foot x 58 foot crew and maintenance building. This building contains three vehicular bays for storage and maintenance of construction equipment used for waste disposal operations as well as offices and washroom facilities for the disposal contractor and the PPL Ash Site Coordinator. Both buildings are of steel-framed, metal-sided construction.

A scale is located off of the entrance road to the silo area. The scale has a capacity of 60 tons and is used to weigh both the waste sent to the disposal area as well as fly ash and bottom ash that is shipped off-site for beneficial use.

Temporary storage of gypsum on Level 2 requires that the gypsum be diverted from its normal route on the conveyor to the U.S. Gypsum wall board plant. A transfer tower will be constructed at the northern edge of the landfill to direct the gypsum to a stackout conveyor. This stackout conveyor will be about 400 feet long and take the gypsum up to Level 2 of the landfill. Several conveyor support bents and foundations will be located on the landfill slopes and several will be located on Level 2.

The transfer tower will be located just outside of the landfill so that none of its foundations will bear on or penetrate the landfill's PVC liner or leachate collection pipes. The conveyor bent foundations will be founded in the disposed fly ash well above the liner and leachate collection system and will also not have any impact on them.

The conveyor to the wallboard plant will be located just outside of the boundary of Ash Area #3. The conveyor foundations will be outside of the landfill waste area and will not impact the liner or leachate collection system.

The locations of the transfer tower and conveyor to the wallboard plant were dictated by the need to avoid wetlands located just north of the landfill.

#### Utilities

Potable water and sanitary facilities are available at the silo area for use by the landfill operations contractor.

#### Construction Sequence Plan

The detailed sequence of construction and ash disposal is shown on Drawing E-195965, Construction Development Sequence Plans. This sequence plan presents the sequential steps to be followed in the construction and operation of the landfill.

This plan is to be worked with the following drawings:

<u>Drawing No.</u>	<u>Title</u>
E-195966, Sht. 1	Preliminary Grading, Stream Diversion, and Roadway - Plan
E-195966, Sht. 2	Leachate and Ground water Underdrain Systems
E-195967	Roadway Profile
E-195968	Preliminary Grading, Stream Diversion, and Roadway - Selections and Details
E-195969	Intermediate Cell Development - Level I
E-195970	Intermediate Cell Development - Level II
E-195971	Intermediate Cell Development - Level III
E-195972	Intermediate Cell Development - Slope Pipe Sections and Details
E-195973	Headwalls - Plan, Sections and Details



<u>Drawing No.</u>	<u>Title</u>
E-195974	Inlets, Manholes and Sump - Plan, Sections and Details
E-195975	Leachate/ Runoff Basin - Enlarged Plan
E-195976	Leachate/ Runoff Basin - Sections and Details
E-195977	Energy Dissipater - Plan, Sections and Details
E-195978	Erosion and Sedimentation Control Plan
E-195979	Isopach of Fill Required
E-195980	Bill of Material
E-195981	List of Reinforcing
E-195982	Geomembrane Liner Installation - Plan and Details
PPC-1990	Ash Disposal Area No. 3 - Erosion and Sedimentation Control Plan Narrative
PPC-2007	Ash Disposal Area No. 3 - Site Development Specification
PPC-2016	Ash Disposal Area No. 3 - Specification for PVC Geomembrane
E-324155	Gypsum Storage Facilities Plan
C-324285	Gypsum Transfer Tower – Cross Section at Landfill and Liner

### Waste Type and Quantity

#### Waste Type and Origin

The predominant waste that would be disposed of in the landfill is fly ash collected in the precipitators of the Montour Steam Electric Station. Fly ash is collected from the station's electrostatic precipitators and pneumatically conveyed in an above-ground pipeline to two steel storage silos located approximately 3,000 feet to the southeast. From the storage silos the fly ash is either removed dry or amended with hydrated lime for beneficial use as stabilized product or for mine reclamation. Fly ash that is not beneficially used is moistened and trucked to the disposal area, end-dumped and then spread and compacted. PPL Ash Operations staff has beneficially utilized all available fly ash produced by the Montour station since the mid 1990's, and no material has been disposed in Ash Area 3.

Other coal combustion products such as boiler bottom ash and coal mill rejects, and smaller amounts of miscellaneous residual and construction/demolition wastes generated at Montour SES are also approved for disposal in the landfill. This includes wastes such as blasting sand, asbestos cement boards from plant cooling towers, refractory material, and demineralizer resin. Bottom ash and mill rejects generated by the Montour Station are presently sluiced to Ash Basin 1 on the plant site. PPL plans to modify bottom ash and mill rejects handling at Basin No.1 in 2007 and 2008. PPL will begin to dispose of Montour mill rejects in Ash Area No. 3 upon completion of these new handling systems.

The largest waste stream currently disposed in Ash Area 3 is mill rejects trucked to Ash Area 3 from PPL's Brunner Island Steam Electric Station in York County, Pennsylvania. Brunner Island mill rejects were a waste stream listed in PPL's Ash Area 3 Form R approved by the Department with issuance of the Ash Area 3 residual waste permit on March 9, 1998. In 2003, PPL requested approval from the Department to temporarily transport Brunner Island mill rejects to Montour Ash Area 3 for disposal. The Department approved this request on April 16, 2003 subject to PPL's submittal of a minor permit modification request if PPL anticipated continued Brunner mill rejects

disposal beyond April 16, 2004. The permit application was submitted and approved by the Department on October 20, 2004.

Brunner Island is in the process of designing a new landfill and expects to submit a permit application to the PADEP Southcentral Office later in 2007. Once the department approves the new landfill at Brunner Island and construction is complete the Brunner Island mill rejects will no longer be disposed at Montour.

Beginning in 2008 Montour anticipates up to 100 tons per day of wastewater treatment plant sludge will be disposed in Ash Area No. 3. The current plans are to transport the sludge to the ash area via a dump trailer or dumpster. PPL will also investigate potential beneficial uses of this material in lieu of disposal.

Synthetic gypsum is a co-product of the power plant flue gas scrubbing operation. Finely ground limestone is mixed with water and sprayed into the power plant flue gas stream. The limestone reacts with the  $\text{SO}_2$  in the flue gas to form calcium sulfite ( $\text{CaSO}_3$ ), which falls into a reaction tank at the bottom of the scrubber absorber vessel. Oxygen is bubbled through the calcium sulfite forming calcium sulfate ( $\text{CaSO}_4$ ) or gypsum. Gypsum is the primary component of wall board. The gypsum is removed from the absorber, dewatered and sent to an adjacent plant via conveyor for the manufacture of wall board. Off-specification gypsum will be temporarily stored on Ash Area No. 3 Level 2 until it can be hauled off site for mine reclamation or other use.

A complete listing of the wastes expected to be disposed of at the landfill can be found in the Form R, Waste Analysis and Classification Plan, submitted with the residual waste permit application. No reactive, unstable, or combustible materials will be disposed of in the landfill.

#### Waste Composition

Fly ash would be the predominant waste stream for the landfill if beneficial ash use programs were suspended. Fly ash consists primarily of metal oxides such as silica ( $\text{SiO}_2$ ), alumina ( $\text{Al}_2\text{O}_3$ ), iron oxide ( $\text{Fe}_2\text{O}_3$ ), calcium oxide or lime ( $\text{CaO}$ ), and magnesium oxide ( $\text{MgO}$ ), along with other minor constituents such as potassium oxide ( $\text{K}_2\text{O}$ ), sodium oxide ( $\text{Na}_2\text{O}$ ), manganese dioxide ( $\text{MnO}_2$ ), sulfur trioxide ( $\text{SO}_3$ ), and unburned carbon. The iron and aluminum oxides and manganese dioxide have high affinities for many trace metals. The specific composition of the fly ash depends upon the type of coal being burned at the plant.

Brunner Island and Montour mill rejects are comprised largely of mineral rich rock containing the normal complement of elements dominated by silicon, aluminum and iron. This material is ejected during the coal milling process to protect equipment and avoid reductions in the BTU content of boiler fuel. Leachate produced by fresh mill rejects is benign with metals content well below hazardous or problem concentrations. Oxidized mill rejects produce a leachate rich in iron and manganese oxides, and minimizing oxidation of mill rejects is a key aspect of managing this waste material.

Wastewater treatment plant sludge is generated during the metals treatment of the Flue Gas Absorber Gypsum dewatering process. The wastewater is treated by standard metals precipitation process and the solids generated from this process is blowdown to a filter press which dewateres the sludge to allow for transportation to Ash Area No. 3 for disposal.

A complete listing and composition of the wastes expected to be sent to Ash Area 3 is included in the facility Form R, Waste Analysis and Classification Plan.



### Waste Quantities

The predominant Ash Area 3 waste would be fly ash if PPL cannot utilize this material beneficially. Montour's recent fly ash production has ranged between 270,000 and 345,000 tons per year. The average amount of ash disposed prior to full initiation of beneficial ash use programs had been approximately 225,000 tons per year. What determines annual production is the amount of ash in the coal, the amount of coal burned, and the amount ash used beneficially. The other potential large volume waste streams are bottom ash and coal mill rejects. Montour SES produces over 100,000 tons of bottom ash per year. All bottom ash sluiced to Basin 1 is now sold and none is sent to Ash Area No. 3, however, the potential exists for disposal.

Montour produces an estimated 3,000 tons of coal mill rejects yearly and expects to begin disposing of this material in Ash Area No.3 in 2007 or 2008 upon completion of the new handling system planned at Ash Basin No.1 along with an estimated 3,000 tons of mill rejects from PPL's Brunner Island Station.

Sludge produced by the scrubber wastewater treatment plant is estimated to be as much as 100 tons per day when the generating units are operating at maximum load. The scrubbers and treatment plant are expected to begin operation in early 2008.

Up to 54,000 tons of synthetic gypsum may be temporarily stored for off-site transport for mine reclamation or, in some situations, possible transfer to the wall board plant. The 54,000 tons represents approximately 15 days of the annual gypsum production total and consists primarily of non-conforming material not acceptable as a raw product for wallboard manufacturing. This is the probable maximum amount of non-conforming product expected to be produced each year and the actual amount is anticipated to be significantly less.

### Proposed Capacity of Landfill

Ash Area No. 3 capacity was determined by cross-sectioning the landfill and performing volume calculations. The capacities of the various cells and levels are as follows:

<u>A and B Cells</u>		<u>C and D Cells</u>	
Level 1	536,628 CY		724,696 CY
Level 2	590,286 CY		737,016 CY
Level 3	330,794 CY		636,293 CY
Total	1,457,708 CY		2,098,005 CY
Total Landfill		3,555,713 CY	

The landfill has been in operation since February 1991 and some of the capacity has been expended. In the A and B Cells, Level 1 and part of Level 2 have been filled. Approximately 1,061,000 tons or 756,000 cubic yards of capacity have been used through the end of 2005.

Total Landfill	3,555,713 CY	
Capacity Used	756,000 CY	
Remaining	2,767,713 CY	as of 12/05

### Expected Life of Facility

The expected lives of the various cells and levels are shown below. The calculations assumed a fly ash density of 91 pounds per cubic foot and an average disposal rate of 225,000 tons per year at 15 percent moisture content or about 160,000 cubic yards per year. The fly ash disposal rate is very dependent on beneficial use demand in addition to the amount of coal burned and the ash content of the coal.

<u>A and B Cells</u>		<u>C and D Cells</u>
Level 1	40 Months	54 Months
Level 2	44 Months	55 Months
Level 3	<u>25 Months</u>	<u>48 Months</u>
Total	109 Months	157 Months
Total Landfill		266 Months or 22 Years and 2 Months (assuming no beneficial use of fly ash)

Approximately 756,000 cubic yards of capacity have been used through the end of 2005. Only Level 1 of the A and B Cells has been completely filled. Approximately 50% of Level 2 capacity has been used.

The most recent capacity report (for 2005 report year) lists a remaining capacity of 3,928,000 tons and an indefinite remaining life because of the small, actual annual disposal volumes.

The synthetic gypsum temporary storage facilities will not impact the disposal of wastes from PPL generating station operations because the area that will be utilized is inactive and not needed for the small volume of wastes being disposed of in the landfill.

If approved for disposal starting in 2008 and if beneficial use of the fly ash continues, wastewater treatment plant sludge will be the largest waste stream (up to 36,000 cubic yards per year) taken to Ash Area No. 3. This annual disposal volume will accelerate the filling of the A and B cells over current rates but the total volume of all wastes will only be about 25% of the originally expected fly ash disposal rate. Level 2 may be filled within 8 years. Level 3 disposal will then have to be reconfigured so that the necessary area is still reserved for the temporary storage of gypsum while providing for continued disposal of approved wastes in the A and B Cells.

### Waste Disposal Operations

#### Operating Plan

The disposal operation will be of the controlled-fill type. Moistened fly ash and other approved wastes will be trucked to the cell and end-dumped. The cell development sequence is as depicted on Development Sequence Plan drawing E-195965. The waste is spread by a bulldozer in one-foot loose layers, and then compacted by a smooth-wheel vibratory roller. The fly ash is delivered to the site at or as near the optimum water content as possible for thorough



compaction. Compaction is a minimum of 90 percent of Modified Proctor (ASTM D1557) maximum density. If this value proves to be unfeasible due to variability of the ash, moisture content or poor weather, it is reviewed by the PPL Disposal Site Coordinator and adjusted as necessary; however, as a minimum, four passes of the vibratory roller is required. The ash is spread and compacted as soon after delivery to the landfill as possible. All unnecessary traffic will be kept off finished fly ash surfaces that are completed to final or temporary grade. The outside slopes of each level are covered with soil and seeded as the landfill height increases. The top of Level 3 will be covered with soil and seeded when it reaches design elevation.

The leachate underdrain system will be checked for blockage prior to the start of fill operations and when the compacted fly ash fill reaches a height of three feet. If any blockages are encountered, they shall be cleared/repared before the disposal of ash continues. This check is made so that blockages are detected before the height of waste over the drains becomes too large to allow correction.

Montour Ash Area 3 receives up to 110 tons per week (five truckloads) of Brunner Island mill rejects with the average being around 60 tons per week. A similar amount of Montour mill rejects is expected to be disposed of in Ash Area No. 3 beginning in late 2007 or 2008. Trucks transporting mill rejects are tarped to minimize oxidation of mill rejects during transport to Montour. Trucks arriving at Ash Area 3 are weighed, and the rejects dumped into specially prepared sites atop level 2 in cells A and B. The mill rejects are spread, and immediately covered with a layer of lime amended fly ash. This seals the mill rejects in lime amended fly ash at the bottom, top and sides eliminating oxidation and providing a lime- rich environment to mitigate any acidic leachate produced by oxidized mill rejects.

Montour Ash Area No. 3 will also begin to receive up to 100 tons per day of wastewater treatment sludge in 2008. Trucks will transport the sludge by tarped dumpster or dump trailer. Trucks arriving at Ash Area 3 are weighed, and the waste sludge will be dumped into prepared cells similar to the proposed methods to handle the disposal of fly ash. The same procedure will be followed as depicted on Development Sequence Plan drawing E-195965. If changes are required PPL will make the appropriate changes and update the 1R and 12R plan.

Active areas of the landfill will be kept as small as possible in order to minimize infiltration of rainfall, limit erosion and prevent dusting problems. In order to prevent storm water ponding, the surface of wastes placed in a disposal cell will be graded to provide positive drainage of storm runoff toward the landfill perimeter where the runoff can be collected by the bench drainage ditches. Particular attention will be given to wastes placed against interior slopes to ensure that water is not trapped against the slope. As described in the Design Concept, the "dirty" runoff from active disposal cells and any other unvegetated area flows to the landfill's Leachate/Runoff basin for sediment removal. From this basin it is then pumped to the power plant's wastewater treatment basin where it is combined with other plant wastewater and treated. If any temporary storm water handling measure is required at an active cell and not shown on the design plans, such as installing a temporary culvert pipe, the Department will be contacted before the measure is implemented.

The active area is outlined on the most recent annual mapping drawing (currently drawing E-324263, 2006 Topographic Mapping). Areas of the landfill that are expected to be inactive for more than six months will have intermediate soil cover placed over it and then be vegetated with the seed mixture approved in the permit.



A portion of the active area will include an area that will be reserved for temporary storage of Stabil-Fill™. This area is also identified on the latest mapping drawing. Stabil-Fill is fly ash that has had a small percentage of lime added to bring the pH of the fly ash within the limits required for disposal and for beneficial use. Stabil-Fill from overloaded trucks will be off-loaded to bring the trucks under the maximum allowable highway gross vehicle weight. Also, when Stabil-Fill intended for offsite beneficial use cannot be hauled to the jobsite because of inclement weather, it will be stockpiled in this temporary storage area. When the weather conditions improve, the Stabil-Fill will be reloaded onto the trucks and hauled off site. In the case of material removed from overloaded trucks, the stockpiled Stabil-Fill will be reloaded onto trucks and hauled off site approximately every two weeks. The total amount of material in temporary storage due to inclement weather will not exceed 2,000 tons and material removed from overloaded trucks will not accumulate above 1,000 tons before it is removed.

Typically, gypsum is conveyed directly from the Montour SES generating units to the U.S. Gypsum manufacturing facility via conveyor. Should testing indicate production of off-specification gypsum unsuitable for wallboard manufacture, the non-conforming material will be directed via a special stackout conveyor to Ash Area 3 Level 2 for off-loading onto a temporary gypsum storage stockpile. A conical pile at the end of the stackout conveyor will accommodate 18,000 tons of gypsum. If a larger quantity of gypsum has to be stockpiled, it will be removed from the conical pile and placed in an adjacent pile. Up to 36,000 tons of gypsum will be placed in this adjacent pile.

For mine reclamation use the gypsum must be blended with lime-amended fly ash. This blending will not take place at Ash Area 3 but at the mine site.

The existing temporary access road to Level 2 (see drawing E324155) will be used to get to the gypsum storage area from the perimeter road.

Temporary access roads are required on the landfill to get the waste from the main landfill entrance point to the active disposal cell. The roads are constructed of coarse, broken shale and segments are abandoned in place when the disposal cell is filled. To prevent leachate from using the more permeable shale as a conduit and breaking out on the slope, all portions of a temporary road within 20 feet of the landfill perimeter will be removed and replaced with compacted, fine-grained Stabil-Fill when it is abandoned. Additionally, an 8'-10' length of an abandoned segment will be removed every 150 feet along its length for its full depth and replaced with compacted Stabil-Fill to interrupt potential seepage flow paths.

Vegetation test plots were established on the landfill at two inactive areas in late 1999. They are identified on the annual topographic mapping drawing. There are plots located on the Level 2 plateau and on an interior slope. These locations are representative of the final plateau and side slopes of the landfill. An evaluation of the vegetative growth on the plots will be made and submitted to the Department. These test plots will remain in place until the plot area is needed for disposal operations or for temporary gypsum storage. At that time the vegetation will be stripped and the soil will be removed and stockpiled for use as cover material. Any synthetic liner and underdrain pipe that was included in the test plot construction will be removed. The surface of the exposed waste will be tracked by disposal equipment before new waste is placed in order to provide a bonding surface.

For gypsum storage the fly ash surface does not need to be tracked after removal of the intermediate cover since a bonding surface is not required. When the gypsum stockpile is removed, the intermediate soil cover will be replaced and vegetation will be re-established.



No salvage of ash placed in the landfill is anticipated at this time.

### Sequence and Timing of Solid Waste Disposal Operations

The cell development sequence is as depicted on Development Sequence Plan drawing E-195965. This sequence plan presents the steps to be followed in the construction and operation of the landfill.

Disposal of fly ash is on-going and usually is done three to five days per week. Montour's historical fly ash production is between 270,000 and 345,000 tons per year. What regulates this is the amount of ash in the coal, the amount of coal burned and ash used beneficially. The average amount of ash disposed prior to full initiation of beneficial ash use programs has been approximately 225,000 tons per year. Fly ash is stored in the steel storage silos when ash disposal operations do not occur, including over weekends and on holidays, with disposal operations continuing on the next workday.

Ash disposal Area No. 3 is a captive facility. It accepts only approved wastes produced by PPL Montour or other PPL facilities and none from other generators. Hence there is no need to post hours of operation.

Temporary gypsum storage will be required only when the material does not conform to the requirements for commercial wallboard. This may occur on initial start-up of the stack gas scrubber units or during scrubber malfunction. Overall it is expected to be an infrequent occurrence.

Disposal of wastewater treatment plant sludge will also be a daily occurrence. Trucks will transport the sludge from the plant area by tarped dumpster or dump trailer.

### Disposal Operation Equipment

The following equipment is used in the disposal operations:

- Dual-axle dump trucks, 25-ton capacity, to haul ash from the silos to the disposal area.
- Rubber-tired bulldozer, Caterpillar Model 824B or equal, to spread the dumped ash in loose lifts of one-foot maximum thickness prior to compaction.
- Vibratory smooth-wheel roller, 20-ton applied force, Hyster Model C625B or equal, to compact the fly ash to the maximum practicable density.
- Truck-mounted hydroseeder, 2,500 gallon capacity, with long-distance and fan-type nozzles, and front and rear water bars. The hydroseeder will be used to spray the compacted ash with water or a dust suppressant in order to minimize dusting and to seed the completed ash cells once they are covered with topsoil.

For emergencies, pumps, generators, backhoes, bulldozers, and other earthmoving equipment are located at the PPL construction crew quarters at Strawberry Ridge or are readily available through other PPL construction offices. Maintenance procedures for all equipment will follow the

manufacturer's recommendations. Because of the type of wastes being disposed there are no possible emergencies which would require equipment decontamination and, therefore, no decontamination equipment is necessary.

#### Erosion and Sedimentation Control

As explained in detail above and on Drawing E-195978, the following measures will be taken to limit erosion and sedimentation:

- All runoff from unvegetated areas will be directed to the Leachate/Runoff Basin for sediment removal.
- Straw bales will be placed at the toe of bare ash slopes if necessary to intercept fly ash and prevent excessive sedimentation of the dirty runoff ditch and runoff basin.
- Immediately after completion of a cell, all outside slopes will be covered with topsoil and seeded.
- Ditches will be grassed or lined with concrete, or other nonerodible material where required by hydraulic or field conditions.
- Discharge from bench drainage ditches to the runoff ditches at the base of the pile will be through slope pipes to prevent erosion of slopes. Discharge will be on splash pads to prevent scour.
- Development of the disposal area on a level-by-level and cell-by-cell basis will minimize the exposed areas to as small an area as possible.
- The top of the final level of ash cells will be covered with topsoil and seeded to completely restore the site to environmentally acceptable conditions.

Fabric filter silt fence will be placed around all temporary gypsum storage stockpiles.

#### Dust Control

The conditioned fly ash, which will have a water content of 14 to 25 percent, is hauled in 25-ton dump trucks a maximum of 3,000 feet from the storage silos to the disposal area. There it is deposited and spread by a bulldozer in one-foot layers and compacted by a 20-ton vibratory roller to 90 percent of its maximum density. Compared to loose disposal methods, compaction of the ash in the disposal area will greatly reduce the amount of dusting. The smooth, tight surface of the fill produced by the smooth-wheel roller greatly reduces any dusting potential. Further, the fly ash is spread and compacted as soon after delivery to the landfill as possible. No uncompacted ash surfaces are permitted. All ash surfaces in the active cells will be rolled smooth by the end of each day's operation and only necessary traffic is permitted on any unprotected ash surfaces.

When the cell height is 75 feet, the top surface will be covered with topsoil and seeded. An active cell area is expected to be four to five acres. Fly ash surfaces, which are completed, but not to



final grade, are sprayed with a dust control agent or covered with bottom ash if the ash surface is disturbed or begins to dust.

The roadways comprising the access and haul roads and silo area consist of approximately 6,300 feet of paved roads and 1,600 feet of gravel-surfaced roads. The paved roads are used most frequently. Dust is controlled in these areas and in the disposal area by cleaning, watering, application of dust control agents, and dust removal. By the end of each workday the areas are clean and free of ash. The dust control equipment, which is intended to be able to perform under all weather conditions, is dedicated to the disposal area and is available for emergency dust control. This equipment consists of:

- A 2,500 gallon truck-mounted hydroseeder equipped with a top-mounted spray gun with long-distance and fan-type nozzles, front and rear mounted water bars controlled from the cab, and a hose and remote nozzle. The pump capacity will be 175 gpm at 100 psi.

A truck wash station at the silo unloading area is used as necessary to wash trucks being loaded with ash. The silo unloading and disposal areas are checked periodically throughout the day. Under emergency (windy) conditions the site coordinator has someone on call at all times, will be notified and will take all measures necessary to control fugitive dusting.

The operation of the disposal area as planned minimizes fugitive dusting.

Dusting from the temporary storage of synthetic gypsum will also be controlled during short-term storage and handling. The gypsum will contain substantial moisture. A moisture content of 10% is the target for synthetic gypsum destined for wallboard manufacture. This moisture content should be sufficient to prevent dusting of materials during the short-term storage period. However, if dusting would still become a problem, the 2,500 gallon capacity truck mounted hydro-seeder equipped with a top-mounted spray gun, and front and rear mounted water bars will be used to wet down the pile as needed. PPL Ash Operations staff will examine the gypsum stockpiles to be sure the material is sufficiently wetted to avoid fugitive dusting. The access drive to the gypsum storage and blending area will also be wetted to minimize dusting.

#### Litter Control

There is no litter associated with facility as it predominantly processes coal combustion wastes.

#### Traffic Control

Most of the residual waste placed in the landfill is hauled over private roads constructed from the storage silo area. Public roads will not be affected. The roadway width is 22 feet, which permits two way traffic flow to and from the landfill.

Sales of fly ash from Ash Area No. 3 and bottom ash from Ash Basin No. 1 or the trucking of Stabil-Fill for beneficial use may generate traffic on the order of 50 trucks per day. Trucking required to haul synthetic gypsum from the temporary storage stockpiles on Level 2 will increase total traffic by approximately 15% assuming that the maximum quantity of 54,000 tons of gypsum is in the storage stockpiles. Nearly all of this traffic will leave the silo area where it is weighed, proceed west on T-414, south on the Washingtonville bypass road (LR 47015), west

on PA 254, and south on PA 54. The intent is to reduce the traffic through the local community to the minimum practicable.

Traffic will also be generated during construction of the C and D cells and especially for the drainage blanket construction when bottom ash is hauled from the plant's Ash Basin No. 1 to the landfill. This traffic is estimated to be on the order of 60 trips per day for several weeks for each of the cells. This traffic will be generated only during the drainage blanket construction for the landfill. It is not expected to impact significantly on the disposal operation or on the local community.

### Safety

No reactive, unstable, or combustible materials will be disposed of in the landfill. All chemical reagents for the treatment of the leachate will be stored and fed at the power plant and not at the landfill.

The contractor responsible for the disposal operations is familiar with the operation of the heavy equipment required in the daily operations. The compacted fly ash will provide stable surfaces for the equipment. Embankment slopes are relatively flat.

All equipment and buildings will be equipped with functional fire extinguishers.

Should an accident occur at the landfill, trained personnel capable of administering first aid are available at the power plant.

### Records

A daily log of all ash placed in the disposal area is kept by the ash disposal contractor. A daily log of all dry ash sales activity is also kept. The logs are given to the PPL Disposal Site Coordinator at the end of each day's operation.

A topographic survey of the landfill is also made annually. The purpose is to reconcile the volume of wastes placed in the landfill with the tonnage figures from the daily logs and to verify that the residual wastes are being placed in the landfill in accordance with the design drawings.

### Communications

A telephone is available at the storage silo area for external communications. The power plant public address system has been extended to the silo area for internal communications with plant personnel. The landfill's emergency response plan lists the telephone numbers of agencies to be contacted in an emergency.



### Employee Training Program

A general environmental education and training program is in place at the Montour SES for all plant personnel. In addition to this program, the contractor responsible for operation of the disposal site is familiar with the safety practices required for that operation and instructs his employees in those procedures. The PPL Site Coordinator is responsible for providing the contractor with specific instructions designed to insure that all environmental concerns are adequately addressed.

### Post-Closure Use of Land and Structures and Site Maintenance

PPL discussed the post-closure use of the land with the PA Department of Agriculture. This has led to a decision to return the land to no-till agricultural production. The Department has recommended that warm season grasses, switchgrass in particular, be grown on the landfill. This use will accomplish two things: it will mitigate the loss of farmland that resulted from the construction of the facility and the switchgrass will provide small game habitat desired by the Game Commission. Only the top of the final lift will be farmed. The side slopes of the landfill are too steep for agriculture and will be open space. Agriculture will be no-till to avoid the possibility of damaging the cap and cap drainage layer.

All ash surfaces will have a topsoil and vegetative cover. This runoff from the site will be discharged to the stream via the clean runoff ditches, while all leachate will continue to be directed to the sump and then pumped to the power plant for treatment. The Leachate/Runoff Basin and the remaining dirty runoff ditches will be filled in, topsoiled, and seeded.

The landfill will require little maintenance after closure; however, inspections of the completed fill will be made and the necessary maintenance performed. The landfill inspections will be covered under an existing formalized inspection program. Inspections will be performed twice per year by qualified personnel. They will also be made after unusually heavy rainfalls. The top of the pile and slopes will be inspected for sinkholes, erosion, cracking, slumping, sliding and the condition of the vegetation. Drainage ditches and culverts will be checked for erosion, pipe blockages, sediment and other debris. The leachate collection system and cap drainage layer system will be checked to make sure that they are functioning. The leachate pumps will be inspected to ensure that they are in operating condition.

It is not known if Ash Area No. 3 will last the life of the Montour Steam Electric Station. If it does not, the fly ash silos, silo area buildings and the weigh scale will remain as part of ash disposal operations supporting a future waste disposal landfill site. This future landfill may be on adjacent power plant property or may be at an off site location. If it does last the life of the power plant, the silos, buildings and scale will be demolished along with the other power plant structures.

Site roadways will remain indefinitely to provide access to the landfill and the leachate pumping facility for maintenance purposes. The leachate pumping system will remain in place and be maintained until leachate quality improves to the point where it can be discharged directly from the landfill without treatment and agency approval is obtained to do so.

## **APPENDIX C**

### **Design Calculations**

**(Attachment 1 to Form I of PPL 2007)**

Dept. \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEETER No. 480230Date 1/5 19 84Designed by JASPROJECT MontourSht. No. 1 of 2

Approved by \_\_\_\_\_

Arch Area #2 Expansion

REVISED 5/96 FOR Q25

(AREA NO. 3)

Site Runoff - Before + After DevelopmentBefore Development

Ref: SCS Engy Field Manual

44 acres Class C soils, row crops straight row: CN = 88  
 17 acres Class D soils, meadow: CN = 78  
 2% slopes

$$\text{Weighted CN} = \frac{44(88) + 17(78)}{61} = 85$$

$$\text{Design storm: } 24 \text{ yr} - 24 \text{ hr} \quad i_{25} = 5.00''$$

$$Q_{10} = 135 \text{ cfs flat slopes (1\%)} \quad Q_{25} = 150 \text{ CFS}$$

$$Q_{10} = 185 \text{ cfs moderate slopes (4\%)} \quad Q_{25} = 220 \text{ CFS}$$

from SCS Fig 2-1

$$Q_{10} = 160 \text{ cfs for 2\% slopes} \quad Q_{25} = 178 \text{ CFS}$$

$$\text{runoff am't} = \frac{2.92}{1.49} \times 61 \text{ acres} \times 43,560 \text{ ft}^2/\text{acre} = 646,575 \text{ ft}^3$$

$$\text{For } Q_{25} = \frac{3.37}{1.49} \times 61 \times 43,560 = 746,217 \text{ ft}^3$$

After Development

Arch pile - 50 acres

23.8 acres, 33% slopes, vegetated CN = 78

26.2 acres, 1% slopes, vegetated CN = 78

Roads + runoff ditches

4 acres, clean, 1% slopes CN = 90

4 acres, dirty, 1% slopes CN = 90

3 acres, road, 1% slopes, CN = 92

$$\text{Weighted CN} = \frac{50(78) + 8(90) + 3(92)}{61} = 80.26 \rightarrow 80$$

$$\text{Weighted slope} = \frac{23.8(33) + 37.2(1)}{61} = 13.5\%$$

Dept. \_\_\_\_\_  
Date 1/5 19 84  
Designed by JAS  
Approved by \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

ER No. 480230  
Sht. No. 2 of 2

PROJECT Mentour SPS  
Ash Area #2 Expansion  
(AREA NO. 3)

REVISED 5/76 FOR Q25

design storm : 25 yr - 24 hr  $i_{55} = 5.00"$   
: 10 yr - 24 hr  $i = 4.50"$

$Q_{25} = 165 \text{ CFS}$   $Q_{10} = 135 \text{ cfs}$  moderate slopes (4%)  
 $Q_{25} = 210 \text{ CFS}$   $Q_{10} = 175 \text{ cfs}$  steep slopes (16%)  
from SC 8 Aug 2-1

$Q_{25} = 205$   $Q_{10} = 170 \text{ cfs}$  for 13.5% slopes.

$$\text{runoff amt} = \frac{2.46}{10} \times 61 \text{ acres} \times 43,560 \frac{\text{ft}^2}{\text{acre}} = 544,717 \text{ ft}^3$$

$$\text{FOR } Q_{25} = \frac{2.89}{10} \times 61 \times 43,560 = 639,932 \text{ FT}^3$$

Change in runoff rate (peak)

$$\frac{205 \text{ CFS} - 178 \text{ CFS}}{170 \text{ cfs} - 160 \text{ cfs}} = \frac{27 \text{ CFS INCREASE FOR } Q_{25}}{+10 \text{ cfs increase}}$$

$$\frac{10}{160} \times 100 = +6.25 \%$$

$$\frac{27}{178} \times 100 = +15.17 \% \text{ FOR } Q_{25}$$

Change in runoff amount

$$\text{FOR } Q_{25} \quad 639,932 \text{ FT}^3 - 746,219 \text{ FT}^3 = -106,287 \text{ FT}^3 \text{ DECREASE}$$

$$544,717 \text{ ft}^3 - 646,575 \text{ ft}^3 = -101,858 \text{ ft}^3 \text{ decrease}$$

$$\frac{101,858 \text{ ft}^3}{646,575 \text{ ft}^3} \times 100 = -15.75 \%$$

$$\frac{106,287 \text{ FT}^3}{746,219 \text{ FT}^3} \times 100 = -14.24 \% \text{ FOR } Q_{25}$$

The 10 cfs increase in peak runoff rate is judged to be too small to have any effect downstream.

FOR THE 25 YEAR STORM, THE PEAK RUNOFF RATE INCREASE IS 27 CFS.  $Q_{25}$  FOR MUD CREEK JUST DOWNSTREAM FROM ASH AREA NO. 3 AT THE LA 47015 BRIDGE IS APPROXIMATELY 3,100\* CFS. ASSUMING SIMULTANEOUS PEAKS:

$$\frac{27 \text{ CFS}}{3,100 \text{ CFS}} \times 100 = 0.87 \% \text{ INCREASE IN FLOW}$$

\* MUD CREEK FREQ-DISCHARGE

JUDGED TO BE NEGLIGIBLE



2-7

$Q_{35} = 178 \text{ CFS}$  UNDEVELOPED

10 year storm

25 YEAR

$Q_{10} = 160 \text{ cfs}$  undeveloped

$i = 4.5 \text{ in}$

$i_{25} = 5.0 \text{ in.}$

$Q_{25} = 205 \text{ CFS}$  DEVELOPED

$Q_{10} = 170 \text{ cfs}$  developed

$A = 61 \text{ acres}$

undeveloped:  $CN = 85, S = 2\%$

developed:  $CN = 80, S = 13.5\%$




Figure 2-1.--Examples of interpolating peak discharge for average watershed slopes between and greater than Flat, Moderate, and Steep

# PEAK RATES OF DISCHARGE FOR SMALL WATERSHEDS TYPE II STORM DISTRIBUTION

10 yr storm 25 YEAR STORM  
 $s = 4.5$  in  $i = 5.0$  in

SLOPES - FLAT  
 CURVE NUMBER - 85

$A = 61$  acres undeveloped

24 HOUR RAINFALL FROM US WB TP-40

$Q_{10} = 135$  cfs - flat slopes

$Q_{25} = 150$  CFS




Exhibit 2-9

REFERENCE

U. S. DEPARTMENT OF AGRICULTURE  
 SOIL CONSERVATION SERVICE  
 ENGINEERING DIVISION - HYDROLOGY BRANCH

STANDARD DWG. NO.

ES- 1027

SHEET 6 of 21

DATE 4-1-66

# PEAK RATES OF DISCHARGE FOR SMALL WATERSHEDS TYPE II STORM DISTRIBUTION

10 yr storm      25 YEAR STORM

$i = 4.5$  in

$i = 5.0$  IN.

SLOPES - MODERATE

CURVE NUMBER - 85

$A = 61$  acres undeveloped

24 HOUR RAINFALL FROM US WB TP-40

$Q_{10} = 185$  cfs - moderate slopes

$Q_{25} = 220$  CFS




Exhibit 2-9

REFERENCE

U. S. DEPARTMENT OF AGRICULTURE  
SOIL CONSERVATION SERVICE  
ENGINEERING DIVISION - HYDROLOGY BRANCH

STANDARD DWG. NO.

ES-1027

SHEET 13 OF 21

DATE 4-1-86

# PEAK RATES OF DISCHARGE FOR SMALL WATERSHEDS TYPE II STORM DISTRIBUTION




Exhibit 2-9

REFERENCE

U. S. DEPARTMENT OF AGRICULTURE  
 SOIL CONSERVATION SERVICE  
 ENGINEERING DIVISION - HYDROLOGY BRANCH

STANDARD DWG. NO.

ES-1027

SHEET 12 of 21

DATE 4-1-66



# PEAK RATES OF DISCHARGE FOR SMALL WATERSHEDS TYPE II STORM DISTRIBUTION




Exhibit 2-9

REFERENCE

U. S. DEPARTMENT OF AGRICULTURE  
 SOIL CONSERVATION SERVICE  
 ENGINEERING DIVISION - HYDROLOGY BRANCH


STANDARD DWG. NO.

ES-1027

SHEET 19 OF 21

DATE 4-1-66

2F/2



# FREQUENCY-DISCHARGE RELATIONSHIP

MUD CREEK

RELOCATION OF LR 47015  
DERRY TOWNSHIP  
MONTGOMERY COUNTY, PA

FIGURE 1

Dept. \_\_\_\_\_  
Date 12/28 19 83  
Designed by JAB  
Approved by \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

ER No. 480230  
Sht. No. 1 of 16

PROJECT Montour  
Art Area #2 Expansion  
(ASK AREA NO. 3)

REVISED 5/96 FOR  
NEW DEVELOPMENT SEQUENCE

# Culvert & Pited Designs

## Summary of Runoff Flows

Design Storm	Rainfall	Site Before Development	Site After Development	Worst Case Dist. During Operation (And I)	Upstream Culvert	Dirty Runoff from West Side of Road
2 yr - 24 hr	2.75 in	75 cfs	60 cfs	48 cfs	46 cfs	1.6 cfs
10 yr - 24 hr	4.50 in	160 cfs	142 cfs	125 cfs	120 cfs	11 cfs
25 yr - 24 hr	5.0 in	185 cfs	172 cfs	143 cfs	150 cfs	15 cfs
50 yr - 24 hr	5.5 in	215 cfs	196 cfs	220 cfs	180 cfs	18 cfs
100 yr - 24 hr	6.3 in	250 cfs	246 cfs	280 cfs	220 cfs	23 cfs

## Basin for Calculations Using SCS Method

- 41 acres, Weighted CN = 85, Weighted slope = 2%
- 50 acres - 8, 4 acres - 7, Weighted CN = 79, Weighted slope = 16%
- 25.7 A+B cells, 51.4 acres, Weighted CN = 90, Weighted slope = 6.5%
- 75 acres, Weighted CN = 77, Weighted slope = 2.3%
- 138 acres, Weighted CN = 53, Weighted slope = 5.6%

51.4 AC NOT POSSIBLE WITH A+B CELLS DEVELOPED BEFORE C+D CELLS.  
JAB spc

Dept. \_\_\_\_\_  
Date 12/29 1983  
Designed by gAB  
Approved by \_\_\_\_\_  
REVISED SKL FOR Q<sub>25</sub>

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

ER No. 480230  
Sht. No. 2 of 16

PROJECT Montour  
High Area #2 Expansion  
(ASH AREA NO. 3)

*Runoff to West Dirty Runoff  
Culvert Below Level I*

*Assume cell C prepared + half filled with ash; All runoff from fly ash except for side slopes is directed to perimeter ditches. Approximate size of Cell C is 800' x 600'.*

*Runoff to Culvert*

*Fly Ash Side Slopes 1000' x 75' = 1.7 acres CN = 90 S = 33%*  
*Bottom Ash 800' x 600' - 1.7 ac = 9.3 acres CN = 53 S = 2%*  
*In cell D Area Between Clean Runoff Ditch + From Embankment 2.8 acres CN = 78 S = 1%*

*CN for bottom ash*

$$CN = \frac{1000}{10 + S}$$

*S = rainfall retention  
in inches*

*void ratios = 0.375*

*for 24" deep layer  $S = 0.375 \times 24" = 9"$*

$$CN = \frac{1000}{10 + 9} = 52.6 \rightarrow 53$$

*Total drainage area = 13.8 acres*

*Weighted CN =  $\frac{1.7(90) + 9.3(53) + 2.8(78)}{13.8} = 62.6 \rightarrow 63$*

*Weighted Slope =  $\frac{1.7(33) + 9.3(2) + 2.8(1)}{13.8} = 5.6\%$*

*Using SCS Manual  $Q_{10} = 11$  cfs*

*$Q_{25} = 15$  cfs*



Dept. \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEETER No. 480230Date 12/13 19 83Designed by JABPROJECT MontourSht. No. 4 of 16

Approved by \_\_\_\_\_

ASH AREA #2 Expansion  
(ASH AREA NO. 3)VERIFIED 5/96 FOR  
Q25

DESIGNER: \_\_\_\_\_

DATE: \_\_\_\_\_

SKETCH# 2400


STATION: \_\_\_\_\_

## HYDROLOGIC AND CHANNEL INFORMATION

$$Q_1 = 147 \text{ cfs } Q_{10} \quad TW_1 = 2.25'$$

$$Q_2 = 172 \text{ cfs } Q_{25} \quad TW_2 = 2.56'$$

( $Q_1$  = DESIGN DISCHARGE, SAY  $Q_{25}$   
 $Q_2$  = CHECK DISCHARGE, SAY  $Q_{50}$  OR  $Q_{100}$ )



## HEADWATER COMPUTATION

CULVERT DESCRIPTION (ENTRANCE TYPE)	Q	SIZE	INLET CONTROL						OUTLET CONTROL				HW = H + h <sub>0</sub> - LS <sub>0</sub>				CONTROLLING VELOCITY	COST	COMMENTS
			HW/D	HW	K <sub>0</sub>	H	d <sub>c</sub>	d <sub>c</sub> +D/2	TW	h <sub>0</sub>	LS <sub>0</sub>	HW	LS <sub>0</sub>	HW	LS <sub>0</sub>	HW			
2 - CIP's w/ Headwall	147	36"	2.0	7.0	0.5	5.5	2.7	2.85	2.25	2.85	0.31	7.99	0.31	7.99	0.31	7.99	14.0		Outlet control
"	172		2.8	8.4		8.0	2.8		2.50										"
2 RCP's w/ Headwall	147		2.0	7.0		3.0	2.7		2.25			7.0		7.0		7.0	10.0		Inlet control
	172		2.8	8.4		4.3	2.8		2.50			8.4		8.4		8.4	12.6		"

## SUMMARY &amp; RECOMMENDATIONS:

The 2-36" RCP's  
 will handle 10 cfs + 25 cfs storm.

Dept. \_\_\_\_\_  
Date 12/13 1983  
Designed by JAS  
Approved by \_\_\_\_\_  
REVISED 5/96 FOR Q25  
FROM NEW DEVELOPMENT SEQ.

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

ER No. 480030  
Sht. No. 5 of 16

PROJECT Montour  
Arch Area #2 Expansion  
(ASH AREA NO. 3)

PROJECT: _____		DESIGNER: _____	DATE: _____	STATION: <u>18+50</u>																
<p><b>HYDROLOGIC AND CHANNEL INFORMATION</b></p> <p> <math>Q_1 = \underline{245 \text{ cfs } Q_{10}}</math> <math>TW_1 = \underline{\hspace{2cm}}</math>  <math>Q_2 = \underline{243 \text{ cfs } Q_{25}}</math> <math>TW_2 = \underline{\hspace{2cm}}</math> </p> <p> <math>(Q_1 = \text{DESIGN DISCHARGE, SAY } Q_{25})</math>  <math>(Q_2 = \text{CHECK DISCHARGE, SAY } Q_{30} \text{ OR } Q_{100})</math> </p>			<p><b>SKETCH: <u>Drainage Runoff Channel</u></b></p> <p> <math>S_0 = 0.005</math>  <math>L = 382'</math>  <math>EL. 524</math>  <math>EL. 512.76</math>  <math>AHW = 7.22'</math>  <math>TW</math>  <math>TW'</math>  <math>Drainage Runoff Channel</math>  <math>Main 5' full</math> </p>																	
CULVERT DESCRIPTION (ENTRANCE TYPE)		Q	SIZE	HEADWATER COMPUTATION					OUTLET CONTROL		INLET CONTROL		INLET CONTROL		OUTLET CONTROL		COMMENTS			
				HW	D	HW	K <sub>0</sub>	H	d <sub>c</sub>	d <sub>c</sub> + D / 2	TW	h <sub>0</sub>	LS <sub>0</sub>	HW	LS <sub>0</sub>	HW	OUTLET VELOCITY	COST		
2-42" p-RCP's w/ dead-end		125	36"	3.4	14.7	14.7	0.5	6.9	3.0	3.0	4.0	4.0	0.28	4.57	4.57	4.57	4.57	15.2		Outlet control
"		143	42"	2.1	7.4	7.4	0.5	5.5	3.5	3.5	4.0	4.0	0.28	4.57	4.57	4.57	4.57	15.2		Outlet control
2-42" p-RCP's w/ dead-end		125	36"	3.4	14.7	14.7	0.5	6.9	3.0	3.0	4.0	4.0	0.28	4.57	4.57	4.57	4.57	15.2		Outlet control
"		143	42"	2.1	7.4	7.4	0.5	5.5	3.5	3.5	4.0	4.0	0.28	4.57	4.57	4.57	4.57	15.2		Outlet control
"		173	42"	2.5	8.8	8.8	0.5	4.5	3.5	3.5	4.0	4.0	0.28	4.57	4.57	4.57	4.57	15.2		Outlet control
"		240	42"	2.5	8.8	8.8	0.5	4.5	3.5	3.5	4.0	4.0	0.28	4.57	4.57	4.57	4.57	15.2		Outlet control

**SUMMARY & RECOMMENDATIONS:** Use 2-42" p-RCP for 10 yr storm  
Will not handle 25 yr storm HW < AHW 5.37 < 7.22' ∴ OK


Dept. \_\_\_\_\_  
Date 12/29 1983  
Designed by g48  
Approved by \_\_\_\_\_  
REVIEWED 5/16/84 Q25

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

PROJECT Montours  
ASH AREA #2 Expansion  
(ASH AREA NO. 3)

ER No. 480230  
Sht. No. 6 of 16

*Dirty Runoff Culvert for West Half of Piped Area*



$$Q_{10} = 11 \text{ cfs} \quad Q_{25} = 15 \text{ CFS}$$

@ Sump

*Preliminary sizing 2-12"  $\phi$  PVC to get under culvert*

$$\frac{P_5}{\gamma} + \frac{V_5^2}{2g} + Z_5 = \frac{P_6}{\gamma} + \frac{V_6^2}{2g} + Z_6 + \frac{0.5V_6^2}{2g} + 1.0 \frac{V_6^2}{2g} + 0.011 \frac{85}{1} \frac{V_6^2}{g}$$

$$V = \frac{11.2}{0.78} = 7.05$$

$$0 + 0 + Z_5 = 4 + 2.43 \frac{7.05^2}{2(32.2)} + 513.50$$

$$Z_5 = 519.37 \quad H.W._5 = \frac{P_5}{\gamma} = 519.37 - 513.93 = 5.44'$$

$$Z_3 = 5.44 + 2.49 \frac{7.05^2}{2(32.2)} + 513.93$$

$$Z_3 = 521.29 \quad H.W._3 = \frac{P_3}{\gamma} = 521.29 - 514.42 = 6.87'$$

$$Z_1 = 6.87 + 2.73 \frac{7.05^2}{2(32.2)} + 514.42$$

$$Z_1 = 523.39' \quad H.W._1 = 523.39 - 515.0 = 8.39'$$

$523.39 > 523.0$   $\therefore$  Can't handle peak FOR Q<sub>10</sub>

Dept. \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEETER No. 480230Date 19Designed by 948PROJECT MontourSht. No. 7 of 16

Approved by \_\_\_\_\_

ASH Area #2 ExpansionREVISED 5/96 FOR  
Q25(ASH AREA NO. 3)Repeat using 1-24"  $\phi$  PVC below MH #2

$$V_{24} = \frac{11}{3.14} = 3.50 \text{ ft/sec.} \quad \text{FOR } Q_{25} \quad V = \frac{15}{3.14} = 4.77 \text{ ft/sec}$$

$$Z_5 = 4 + 2.43 \frac{3.50^2}{2(32.2)} + 513.50$$

$$\text{FOR } Q_{10} \quad Z_5 = 517.96 \quad H.W._4 = \frac{P_4}{\gamma} = 517.96 - 513.93 = 4.03'$$

$$\text{FOR } Q_{25} \quad Z_5 = 518.35 \quad H.W._4 = 518.35 - 513.93 = 4.43'$$

$$\text{FOR } Q_{10} \quad Z_3 = 4.03 + 2.49 \frac{3.50^2}{2(32.2)} + 513.93$$

$$\text{FOR } Q_{10} \quad Z_3 = 518.43 \quad H.W._3 = \frac{P_3}{\gamma} = 518.43 - 514.42 = 4.01'$$

$$\text{FOR } Q_{25} \quad Z_3 = 519.24 \quad H.W._3 = 519.24 - 514.42 = 4.82'$$

$$\text{FOR } Q_{10} \quad Z_1 = 4.01 + 2.73 \frac{3.50^2}{2(32.2)} + 514.42$$

$$\text{FOR } Q_{10} \quad Z_1 = 518.95 \quad H.W._1 = 518.95 - 515.0 = 3.95'$$

$$518.95 < 523.0 \quad \therefore \text{O.K.}$$

Use 2-12"  $\phi$  from headwall to MH #2 and 24"  $\phi$  from MH #2 to ramp.

$$\rightarrow \text{FOR } Q_{25} \quad Z_1 = 4.82 + 2.73 \frac{(4.77)^2}{2(32.2)} + 514.42$$

$$Z_1 = 520.20 < 523.0 \quad \therefore \text{OK FOR } Q_{25}$$




Dept. \_\_\_\_\_  
Date \_\_\_\_\_ 19\_\_\_\_  
Designed by gkb  
Approved by \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

ER No. 480230  
Sht. No. 8 of 16

PROJECT Montour  
Ash Area #2 Expansion  
(ASH AREA No. 3)

*Trapezoidal ditch design below Culverts*



$$Q = \frac{1.486 A n^{1/3}}{n}$$

$$\begin{aligned} \text{area } A &= bd + z d^2 \\ \text{perimeter } p &= b + 2d\sqrt{z^2 + 1} \\ n &= \frac{A}{P}, \quad n = \frac{Q}{A} \end{aligned}$$

for  $b = 6'$ ,  $z = 2$ ,  $s = 0.005$ ,  $n = 0.023$

Assumed d	A	p	n	Q	n
0.5	3.50	8.24	0.42	9.00	2.57
1.0	8.00	10.47	0.76	30.40	3.80
1.5	13.50	12.70	1.02	62.63	4.64
2.0	20.00	14.94	1.34	111.16	5.56
2.5	27.50	17.17	1.60	172.22	6.26
3.0	36.00	19.41	1.85	248.78	6.90

for  $b = 10'$ ,  $z = 2$ ,  $s = 0.005$ ,  $n = 0.023$

Assumed d	A	p	n	Q	n
0.5	5.50	12.23	0.45	14.70	2.67
1.0	12.00	14.47	0.83	48.36	4.06
1.5	19.50	16.71	1.17	98.81	5.07
2.0	28.00	18.94	1.47	165.59	5.91
2.5	37.50	21.17	1.77	251.25	6.70

Dept. \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEETER No. 480230Date 19Designed by g#3

PROJECT

Mentour  
Arch Area #2 Expansion  
(154 AREA NO. 3)Sht. No. 9 of 16

Approved by \_\_\_\_\_

$$for L = 16', Z = 2, S = 0.001, n = 0.023$$

Assumed d	A	P	m	Q	n
0.5'	8.50	18.23	0.47	10.41	1.23
1.0'	18.00	20.47	0.88	33.74	1.87
1.5'	28.50	22.71	1.25	67.80	2.38
2.0'	40.00	24.94	1.60	112.15	2.80
2.5'	52.50	27.17	1.93	166.77	3.17
3.0'	66.00	29.41	2.24	231.76	3.51
3.5'	80.50	31.65	2.54	307.13	3.81

Ditch Section	Q 25	Channel Width	Slope	Depth of Flow	Velocity
Clean Runoff	172 cfs	10'	0.005	2.1'	6.0 ft/sec
Below Stream Enclosure	150 cfs	16'	0.001	2.4'	3.1 ft/sec
Below junction of above	322 cfs	16'	0.001	3.6'	3.9 ft/sec

Dept. \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEETER No. 480230Date        19       Designed by JABPROJECT MontourSht. No. 10 of 16

Approved by \_\_\_\_\_

Bed Area #2 Expansion*Channel Protection Downstream  
of Culverts @ South End of Site**Reference: "Design of Roadside Drainage Channels"  
FHWA**Outlet velocity of culverts : 10 ft/sec (Culvert cases)**from Fig. 21  $P_{50} = 0.8 \text{ ft} \approx 10''$* *from Fig 24 use the following gradation*

100 %	passing 18" screen	(by weight)
60-75 %	passing 12" screen	"
35-55 %	passing 9" screen	"
15-30 %	passing 6" screen	"
0-10 %	passing 3" screen	"

Sheet 11 of 14




Figure 21.—Size of stone that will resist displacement for various velocities and side slopes.

and of fairly uniform thickness are much easier to place than irregular stones. Stones of a flat stratified nature should be placed with the principal bedding planes normal to the slope. Openings to the subsurface should be filled with rock fragments; however, enough voids or openings should be left to vent the subsurface properly.

**5.8 Ditch checks.** Ditch checks must be firmly anchored into the banks of the drainage channels. The choice of material determines the methods used, but all

checks should have a suitable apron at the toe of the drop and a cutoff wall at the downstream end of the apron. The apron should have a depression or a sill at the downstream edge so that a pool will be created to dissipate the energy of the falling water. If clay is available, local stone can be laid up in a rich clay mortar. This makes the check almost watertight and results in less maintenance than if the stones are laid up loose with the expectation that the check will become impermeable in time.




Figure 24.—Gradation curves for dumped-stone protection.



Dept. \_\_\_\_\_  
Date \_\_\_\_\_ 19\_\_\_\_  
Designed by JAB  
Approved by \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

PROJECT Montour  
Rock Area #2 Expansion

ER No. 480230

Sht. No. 13 of 16

Filter Design for Riprap

<u>Soil (Samples 104+13A)</u>	<u>Riprap</u>
$D_{10}$ 0.004 mm	100 mm
$D_{15}$ 0.008 mm	125 mm
$D_{50}$ 2.04 mm	250 mm
$D_{60}$ 2.045 mm	300 mm
$D_{85}$ 0.05 mm	375 mm
$C_u = \frac{D_{60}}{D_{10}} = 11.25$	$C_u = \frac{300}{100} = 3$

Requirements

- To avoid head loss:  $\frac{D_{15F}}{D_{15B}} > 4$
- To avoid piping:  $\frac{D_{15F}}{D_{85B}} < 5$ ,  $\frac{D_{50F}}{D_{50B}} < 25$ ,  $\frac{D_{15F}}{D_{15B}} < 20$   
 if base  $C_u < 1.5$   $\frac{D_{15F}}{D_{85B}} < 6$   
 if base  $C_u > 4$   $\frac{D_{15F}}{D_{15B}} < 40$
- No size in filter  $> 3"$  and not more than 5% passing #200.

Is a filter required?

$$\frac{P_{15 \text{ riprap}}}{P_{85 \text{ soil}}} = \frac{125}{0.05} = 2500 > 5 \therefore \text{Yes}$$

Dept. \_\_\_\_\_

Date \_\_\_\_\_ 19 \_\_\_\_\_

Designed by gds

Approved by \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

PROJECT Montour

Risk Area #2 Expansion

ER No. 480230

Sht. No. 14 of 16

$$\frac{D_{15} \text{ filter}}{D_{15} \text{ soil}} > 4, \quad D_{15} \text{ filter} > 4(0.008) \text{ or } 0.032 \text{ mm} \quad \underline{\text{lower limit}}$$

$$\frac{D_{15} \text{ filter}}{D_{85} \text{ soil}} < 5, \quad D_{15} \text{ filter} < 5(0.05) \text{ or } 0.25 \text{ mm} \quad \underline{\text{upper limit}} \quad \text{controls}$$

$$\frac{D_{50} \text{ filter}}{D_{50} \text{ soil}} < 25, \quad D_{50} \text{ filter} < 25(0.04) \text{ or } 1.0 \text{ mm} \quad \underline{\text{upper limit}}$$

$$\frac{D_{15} \text{ filter}}{D_{15} \text{ soil}} < 40, \quad D_{15} \text{ filter} < 40(0.008) \text{ or } 0.32 \text{ mm} \quad \underline{\text{upper limit}}$$

$$\frac{D_{15} \text{ riprap}}{D_{85} \text{ filter}} < 5, \quad D_{85} \text{ filter} > \frac{125}{5} \text{ or } 25 \text{ mm} \quad \underline{\text{lower limit}}$$

$$\frac{D_{50} \text{ riprap}}{D_{50} \text{ filter}} < 25, \quad D_{50} \text{ filter} > \frac{250}{25} \text{ or } 10 \text{ mm} \quad \underline{\text{lower limit}}$$

$$\frac{D_{15} \text{ riprap}}{D_{15} \text{ filter}} < 20, \quad D_{15} \text{ filter} > \frac{125}{20} \text{ or } 6 \text{ mm} \quad \underline{\text{lower limit}}$$

Two filter layers will be required.

Dept. \_\_\_\_\_  
Date \_\_\_\_\_ 19\_\_\_\_  
Designed by JAB  
Approved by \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

PROJECT Montour  
Arch Area #2 Expansion

ER No. 480230  
Sht. No. 15 of 16

$$\frac{D_{15} \text{ filter 2}}{D_{85} \text{ filter 1}} < 5, \quad D_{15} \text{ filter 2} < 5(8) \text{ or } 40 \text{ mm}$$

upper limit  
\* Controls

$$\frac{D_{50} \text{ filter 2}}{D_{85} \text{ filter 1}} < 25, \quad D_{50} \text{ filter 2} < 25(0.7) = 17.5 \text{ mm}$$

upper limit


$$\frac{D_{15} \text{ filter 2}}{D_{85} \text{ filter 1}} < 40, \quad D_{15} \text{ filter 2} < 40(8) \text{ or } 320 \text{ mm}$$

upper limit

Filter 1 + Filter 2 shown on attached  
grain size distribution plot.

Skt. 16 g/16

# GRAIN SIZE DISTRIBUTION



PERCENTAGES FINER BY WEIGHT

Dept. PPA  
Date 12/9 1983  
Designed by WJB  
Approved by \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

ER No. \_\_\_\_\_  
Sht. No. 19 of 22

PROJECT MONTGOMERY SE3  
(ASH AREA NO. 3)  
ASH DISPOSAL AREA 5-6

REVISED 3/96 FOR  
Q25

P10 EXCE.  
AS NOTED

LEVEL	DITCH/PIPE TO BE SIZED	CONTRIBUTING AREA	SLOPE %	CN	AREA (AC)	TOTAL AREA	WEIGHTED S	WEIGHTED CN	DESIGN Q.
I	SLOPE PIPE WEST SIDE	WEST SIDE TOP OF PILE	1	90	20.8	20.8	1	90	78; Q25=6
I	WEST DITCH	HAUL ROAD SLOPE	33	92 90	1.0 3.4	4.4	26	90	22 Q25=0
I	SOUTH WEST DITCH	HAUL ROAD PILE SLOPE TOP OF PILE	1 33 1	92 90 90	1.3 4.7 20.8	26.8	7	90	Q25=1 116
I	EAST SIDE SLOPE PIPE	EAST SIDE TOP OF PILE	1	90	19.7	19.7	1	90	Q25=6 78
I	EAST SIDE DITCH	HAUL ROAD SLOPE	33	92 90	.9 3.4	4.3	26	90	Q25=0 22
I	SOUTH EAST DITCH	HAUL ROAD PILE SLOPE TOP OF PILE	1 33 1	92 90 90	1.1 3.8 19.7	24.6	6	90	Q25=16 100
II	SLOPE PIPE WEST SIDE	WEST SIDE TOP OF PILE	1	90	14.75	14.75	1	90	Q25=5 62
I	WEST SIDE BENCH DITCHES	WEST SLOPE LEVEL II BENCH LEVEL I	33 1	78 90	4.2 1.2	5.4	26	80	Q25=0 11
II	SLOPE PIPE EAST SIDE	EAST SIDE TOP OF PILE	1	90	15.5	15.5	1	90	Q25=3 60
I	EAST SIDE BENCH DITCHES	EAST SLOPE II EAST BENCH I	33 1	78 90	4.1 1.0	5.2			Q25=0 21
III	WEST SIDE SLOPE PIPE	WEST SIDE TOP OF PILE	1	90	10.7	10.7	1	90	Q25=4
III	EAST SIDE SLOPE PIPE	EAST SIDE TOP OF PILE	1	90	11.24	11.24	1	90	Q25=4
ALL	SOUTH WEST CLEAN DITCH	TOP LEVEL III SLOPE LEVEL III BENCH II SLOPE II BENCH I SLOPE I	1 33 1 33 1 33	78 78 90 78 90 78	10.70 3.51 1.04 4.2 1.2 4.7	25.35	16	79	Q25=7



Dept. \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

ER No. \_\_\_\_\_

Date \_\_\_\_\_ 19\_\_\_\_

Designed by WJB

PROJECT \_\_\_\_\_

Sht. No. 16 of 52

Approved by \_\_\_\_\_

JAS REVISED 5/96  
FOR Q25

LEVEL	DITCH/PIPE TO BE SIZE	CONTRIBUTING AREA	SLOPE %	CN	AREA (AC)	TOTAL AREA	WEIGHTED S	WEIGHTED CN	DESIGN Q C
ALL	SOUTHEAST CLEAN DITCH	EAST TOP LEVEL III	1	78	11.24	24.66	16	79	Q25 = 7.
		SLOPE LEVEL III	33	78	3.48				
		BENCH II	1	90	1.04				
		SLOPE II	33	78	4.10				
		BENCH I	1	90	1.0				
		SLOPE I	33	78	3.8				
ALL	CLEAN RUNOFF CULVERTS	WEST TOP III	1	78	10.70	50.01			Q25 = 142
		EAST TOP III	1	78	11.24				
		W SLOPE III	33	78	3.51				
		E SLOPE III	33	78	3.48				
		BENCH II, W	1	90	1.04				
		BENCH II, E	1	90	1.04				
		W. SLOPE II	33	78	4.2				
		E. SLOPE II	33	78	4.10				
		W. BENCH I	1	90	1.2				
		E. BENCH I	1	90	1.0				
		W. SLOPE I	33	78	4.7				
		E. SLOPE I	33	78	3.8				

Dept. \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

ER No. \_\_\_\_\_

Date \_\_\_\_\_ 19 \_\_\_\_\_

Designed by WJB

PROJECT \_\_\_\_\_

Sht. No. 2 of 22

Approved by \_\_\_\_\_

REVISED 5/96 FOR Q<sub>25</sub>

WEST SLOPE PIPE -

DESIGN STORM 25 YR - 24 HR  
~~10 yr - 24 hr.~~, TYPE II

$L = 4.5$  in. from Exhibit 2-3 Sht 3

$i = 5.0$  in FOR Q<sub>25</sub>

PEAK Q:

Q<sub>25</sub> = 65 CFS ←

for flat slopes

Q = 78 cfs ~~XXXXXXXXXX~~

WEST DITCH -

WEIGHTED S:

$$\frac{1.0(1) + 3.4(33)}{4.4} = 25.7 \text{ say } 26$$

WEIGHTED CN:

$$\frac{1.0(92) + 3.4(90)}{4.4} = 90.5 \text{ say } 90$$

DETERMINE PEAK Q:

for Moderate Slope (4%)

Q = 22 cfs Q<sub>25</sub> = 23 CFS

for steep Slope (16%)

Q = 22 cfs Q<sub>25</sub> = 23 CFS

∴ Q = 22 cfs ~~XXXXXXXXXX~~  
Q<sub>25</sub> = 23 CFS ←

WEST SOUTH DITCH -

WEIGHTED S:

$$\frac{1.3(1) + 4.7(33) + 20.0(1)}{26.0} = 6.6 \text{ say } 7\%$$

WEIGHTED CN:

$$\frac{1.3(92) + 4.7(90) + 20.0(90)}{26.0} = 90.1 \text{ say } 90$$

DETERMINE PEAK Q:

for Moderate Slope (4%)

Q = 115 cfs Q<sub>25</sub> = 125 CFS

for steep slope (16%)

Q = 118 cfs Q<sub>25</sub> = 145 CFS

Dept. \_\_\_\_\_  
Date \_\_\_\_\_ 19 \_\_\_\_\_  
Designed by WVB  
Approved by \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

ER No. \_\_\_\_\_  
Sht. No. 3 of 22

REVISED 5/96 FOR Q<sub>25</sub>

EAST SLOPE PIPE -

55 YEAR - 24 HOUR

DESIGN STORM 10 yr = 24 hr TYPE II

$$L = 4.5$$

$$L = 5.0 \text{ IN FOR } Q_{25}$$

$$Q_{25} = 64 \text{ CFS}$$

PEAK Q: for flat slopes

$$Q = 78 \text{ cfs X}$$

EAST DITCH -

WEIGHTED S

$$\frac{9(1) + 3.4(33)}{4.7} = 26.3 \text{ say } 26$$

WEIGHTED CN

$$\frac{9(92) + 3.4(90)}{4.7} = 90.4 \text{ say } 90$$

DETERMINE PEAK Q

for Moderate Slope (4%)

$$Q = 22 \quad Q_{25} = 23 \text{ CFS}$$

for steep Slope (16%)

$$Q = 22 \quad Q_{25} = 23 \text{ CFS}$$

for 26% slope:

$$Q_{25} = 23 \text{ CFS} \leftarrow$$

$$Q = 22 \text{ cfs } \text{XXXXXXXXXX}$$

SOUTHEAST DITCH

WEIGHTED S:

$$\frac{1.1(1) + 3.8(33) + 19.7(1)}{24.6} = 5.9 \text{ say } 6$$

WEIGHTED CN:

$$\frac{1.1(92) + 3.8(90) + 19.7(90)}{24.6} = 90$$

DETERMINE PEAK Q

for Moderate Slope (4%)

$$Q = 108 \text{ cfs} \quad Q_{25} = 115 \text{ CFS}$$

for steep Slope (16%)

$$Q = 110 \text{ cfs} \quad Q_{25} = 125 \text{ CFS}$$

from Fig 2.1 for 6%

$$Q = 109 \text{ cfs } \text{XXXXXXXXXX}$$

$$Q_{25} = 120 \text{ CFS } \leftarrow$$

Dept. \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

ER No. \_\_\_\_\_

Date \_\_\_\_\_ 19 \_\_\_\_\_

Designed by WJB


PROJECT \_\_\_\_\_

Sht. No. 4 of 22

Approved by \_\_\_\_\_

SIZE EAST DITCH

MIN. SLOPE OCCURS FROM STA 18+50 TO STA 27+00



ASSUME MIN. CONCRETE COVER OVER 48" PIPES IS 3"

∴ @ STA 19+84.4 MIN. DITCH ELEV = 520.46

$$\begin{aligned} \text{MAX SLOPE OF DITCH} &= \frac{522.00 - 520.55}{2700 - 1984.4} = .0020 \end{aligned}$$

DETERMINE DEPTH OF FLOW -

(REF. TABLE 12 pg 255 SCHUMM'S OUTLINE - FLUID MECH. & HYD.)

$$Q = (K'/n) b^{2/3} S^{1/2}$$

$$22 = K'/.023 (4)^{2/3} (.002)^{1/2}$$

$$K' = .2806 \Rightarrow y/b = .32 = \frac{y}{4} \therefore y = 1.28 \text{ ft.}$$

TRY  $S = .0015$

$$Q = (K'/n) b^{2/3} S^{1/2}$$

$$22 = K'/.023 (4)^{2/3} (.0015)^{1/2}$$

$$K' = .324 \Rightarrow y/b = .344$$

$$y = 1.376$$

$$\frac{x-.34}{.02} = \frac{.008}{.037}$$

$$x = .344$$

$$.34 \quad .316$$

$$x \quad .324$$

$$.36 \quad .353$$

Dept. \_\_\_\_\_  
Date \_\_\_\_\_ 19\_\_\_\_  
Designed by WLB  
Approved by \_\_\_\_\_


PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

PROJECT \_\_\_\_\_

ER No. \_\_\_\_\_  
Sht. No. 5 of 22

SIZE SOUTH DITCH -

ELEV. DITCH @ STA 24+00 = 521.55



MIN CONCRETE COVER 1.5"  $\therefore$  ELEV @ STA 19+84.4 = 520.36

$$\text{MAX SLOPE} = \frac{521.55 - 520.36}{2400 - 1984.4} = .00286$$

ELEV @ 18+50 = 520.

$$\therefore \text{SLOPE} = \frac{521.55 - 520.0}{2400 - 1850} = .00282 \quad \leftarrow \text{USE}$$

DETERMINE DEPTH OF FLOW -

NOTE - DITCH CONCRETE LINED

$$Q = (K'/n) b^{2/3} s^{1/2}$$

$$116 = K'/.013 (4)^{2/3} (.00282)^{1/2}$$

$$K' = .7043$$

.679	.5	$\frac{X-.5}{.05} = \frac{.025}{.147}$
.704	X	
.826	.55	

$$y/b = .509 \Rightarrow y = 2.04' \text{ OK}$$

$$X = .509$$



Dept. \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

ER No. \_\_\_\_\_

Date \_\_\_\_\_ 19 \_\_\_\_\_

Designed by WJB

PROJECT \_\_\_\_\_

Sht. No. 6 of 22

Approved by \_\_\_\_\_

SOUTH EAST DITCH

$$\text{SLOPE} = \frac{522 - 520}{18+50 - 13+50} = .004 \quad (\text{CONCRETE LINED})$$

$$\text{SLOPE} = \frac{532 - 522}{13+50 - 6+60} = .0145 \quad (\text{NATURAL SOIL})$$

DETERMINE DEPTH OF FLOW -

$$Q = (K'/n) b^{2/3} s^{1/2}$$

$$109 = (K'/.013) (4)^{2/3} (.004)^{1/2}$$

$$K' = .556$$

$$.525 \quad .44$$

$$.556 \quad x$$

$$.574 \quad .46$$

$$\frac{y - .44}{.02} = \frac{.031}{.049}$$

$$x = .453$$

$$y/b = .453$$

$$y = 1.812' \quad (\text{Concrete})$$

$$109 = (K'/.023) (4)^{2/3} (.0145)^{1/2}$$

$$K' = .516$$

$$.478 \quad .42$$

$$.516 \quad x$$

$$.525 \quad .44$$

$$\frac{x - .42}{.02} = \frac{.038}{.047}$$

$$x = .436$$

$$y/b = .436$$

$$y = 1.744' \quad (\text{Soil})$$

EAST SIDE DITCHBY INSPECTION DITCH OK

Dept. \_\_\_\_\_  
Date \_\_\_\_\_ 19\_\_\_\_  
Designed by WJB  
Approved by \_\_\_\_\_


PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

PROJECT \_\_\_\_\_

ER No. \_\_\_\_\_

Sht. No. 7 of 22

SIZE LEVEL I SLOPE PIPES



ASSUME 36" Ø, 30" Ø SLOPE PIPE

$$Q_2 = Q_3$$

$$V_{36} A_{36} = V_{30} A_{30}$$

$$V_{36} (7.069) = V_{30} (4.909)$$

$$V_{36} = .6944 V_{30}$$

BERNOULLI Eq:

$$\frac{V_1^2}{2g} + \frac{P_1}{\gamma} + z_1 = \frac{V_3^2}{2g} + \frac{P_3}{\gamma} + z_3 + \sum h_f$$

$$539.9 = \frac{V_3^2}{2g} + 524.25 + \sum h_f$$

$$15.65 = \frac{V_3^2}{2g} + \sum h_f \quad (1)$$

Dept. \_\_\_\_\_  
Date \_\_\_\_\_ 19\_\_\_\_  
Designed by WJB  
Approved by \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

PROJECT \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

ER No. \_\_\_\_\_  
Sht. No. 8 of 22

MINOR LOSSES:

ENTRANCE  $\frac{.5 V_{30}^2}{2g} = \frac{.24 V_{30}^2}{2g}$

1ST BEND  $\frac{.17 V_{30}^2}{2g} = \frac{.08 V_{30}^2}{2g}$

CONTRACTION  $\frac{.08 V_{30}^2}{2g}$

2ND BEND  $\frac{.17 V_{30}^2}{2g}$

$h_m = \frac{.57 V_{30}^2}{2g}$

FROM (1)  $15.65 = \frac{V_{30}^2}{2g} + \frac{.57 V_{30}^2}{2g} + h_f$

$15.65 = 1.57 \frac{V_{30}^2}{2g} + h_f$

$15.65 = 1.57 \frac{V_{30}^2}{2g} + 5.93$

$V_{30} = 19.97 \text{ f/s}$

$Q = VA$

$= 19.97 (4.909)$

$= 98 \text{ cfs} > 78 \text{ cfs} \therefore \text{OK}$

ASSUMING  $Q = 78 \text{ cfs}$   
USING ASCE SEWER DESIGN MANUAL

$h_{f36} = \frac{35}{1000} \times 30 = 1.05$

$h_{f30} = \frac{75}{1000} \times 65 = \frac{4.88}{5.93}$

Dept. \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

ER No. \_\_\_\_\_

Date \_\_\_\_\_ 19 \_\_\_\_\_

Designed by WJB

PROJECT \_\_\_\_\_

Sht. No. 9 of 22

Approved by \_\_\_\_\_

REVIS REVISED 5/16 FOR Q<sub>25</sub>

WEST SLOPE PIPE LEVEL II

DESIGN STORM <sup>55 YR - 24 HOUR</sup>  
~~10 yr - 24 hr~~, TYPE II  
i = 4.5 IN from Exhibit 2-3 sht 3  
i = 5.0 IN FOR Q<sub>25</sub> Q<sub>25</sub> = 50 CFS  
PEAK Q - for flat slopes Q = 62 cfs X

WESTSIDE BENCH DITCHES -

WEIGHTED S:  $\frac{4.2(33) + 1.2(1)}{5.4} = 25.9$  say 26

WEIGHTED CN:  $\frac{4.2(78) + 1.2(90)}{5.4} = 80.7$  say 80  
← SEEDED

DETERMINE PEAK Q

for moderate slope (4%) Q = 16 Q<sub>25</sub> = 21

for steep slope (16%) Q = 16 Q<sub>25</sub> = 21

Q<sub>25</sub> = 21 CFS  
∴ Q = 16 cfs @ 20% slope

CHECK LEVEL I BENCH DITCH -

CRITICAL DITCH HAS S = .00441 d<sub>max</sub> = 2.5'

FOR "V" DITCH n = .023 S = .00441 - Assume d = 1.5' Q<sub>DES</sub> = 16 cfs

TRIAL	assumed d	A (ft <sup>2</sup> )	p	r	V (ft/s)	Q (cfs)
1	1.5	6.75	9.49	.711	3.4	22.95 > 16 ∴ OK

CHECK DITCH FOR CAPACITY PRIOR TO LEVEL II

ASSUME Q = 1/2 Q<sub>max</sub> = 1/2 (78) = 39 cfs (ONLY 1/2 AREA CONTRIBUTES TO CRITICAL DITCH)

2	2.0	12.00	12.65	.949	4.05	48.6 > 39 ∴ OK
---	-----	-------	-------	------	------	----------------

BENCH DITCH OK - DOESN'T EXCEED d<sub>max</sub> = 2.5'

Dept. \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

ER No. \_\_\_\_\_

Date \_\_\_\_\_ 19\_\_\_\_

Designed by WVB

PROJECT \_\_\_\_\_

Sht. No. 10 of 22

Approved by \_\_\_\_\_

CHECK LEVEL II BENCH DITCH -CRITICAL DITCH HAS  $S = .0048$   $d_{max} = 2.0'$ 

CHECK DITCH CAPACITY PRIOR TO LEVEL III

ASSUME  $Q = \frac{1}{2} Q_{max} = \frac{1}{2} (63) = 31.5$  cfs

$$n = 0.023$$

$$Q = \frac{1.486 A s^{1/2} r^{2/3}}{n}$$

<u>TRIAL</u>	<u>Assumed</u> <u>d</u>	<u>A</u>	<u>P</u>	<u>r</u>	<u>V (ft/s)</u>	<u>Q (cfs)</u>
1	2.0	12	12.65	.949	4.2	50.4

$$31.5 < 50.4 \quad \therefore \text{OK}$$

NOTE: ALTHOUGH DITCH WILL FLOW RELATIVELY FULL THIS IS A TEMPORARY DITCH AND WILL NOT BE IN USE FOR MANY YEARS. WHEN LEVEL III IS CONSTRUCTED RUNOFF WILL BE SIGNIFICANTLY LESS.



Dept. \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

ER No. \_\_\_\_\_

Date \_\_\_\_\_ 19 \_\_\_\_\_

Designed by WVB


PROJECT \_\_\_\_\_

Sht. No. 11 of 22

Approved by \_\_\_\_\_

SIZE LEVEL II SLOPE PIPES -

HEAD WATER DEPTH = 5.1'  
WHICH IS OK FOR  
INLET CONTROL W/ 36"  $\phi$  PIPE



ASSUME 36"  $\phi$   $\div$  30"  $\phi$

$$Q_{36} = Q_{30}$$

$$V_{36} A_{36} = V_{30} A_{30}$$

$$V_{36} (7.069) = V_{30} (4.909)$$

$$V_{36} = .6944 V_{30}$$

BERNOULLI Eq: ①  $\rightarrow$  ③

$$\frac{V_1^2}{2g} + \frac{P_1}{\gamma} + z_1 = \frac{V_2^2}{2g} + \frac{P_2}{\gamma} + z_2 + \sum h_f$$

$$561.4 = \frac{V_{30}^2}{2g} + 529.25 + h_m + h_f$$

Dept. \_\_\_\_\_  
Date \_\_\_\_\_ 19\_\_\_\_  
Designed by WVR  
Approved by \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

PROJECT \_\_\_\_\_

ER No. \_\_\_\_\_

Sht. No. 12 of 22

MINOR LOSSES:

$$\text{ENTRANCE} = \frac{.5 V_{30}^2}{2g} \equiv \frac{.24 V_{30}^2}{2g}$$

$$1^{\text{ST}} \text{ BEND} = \frac{.17 V_{30}^2}{2g} \equiv \frac{.08 V_{30}^2}{2g}$$

$$\text{CONTRACTION} = \frac{.08 V_{30}^2}{2g}$$

$$3 \text{ BENDS} = \frac{3 (.17 V_{30}^2)}{2g} \equiv \frac{.51 V_{30}^2}{2g}$$

$$\underline{\underline{\frac{.91 V_{30}^2}{2g}}}$$

FRICTION LOSSES:

Assuming  $Q = 63 \text{ cfs}$ , USING ASCE SEWER DESIGN MANUAL

$$h_{f_{36}} = \frac{25}{1000} \times 30 = .75$$

$$h_{f_{30}} = \frac{55}{1000} \times 132 = \frac{7.26}{8.01}$$

$$\therefore 561.4 = \frac{V_{30}^2}{2g} + 529.25 + \frac{.91 V_{30}^2}{2g} + 8.01$$

$$24.14 = \frac{1.91 V_{30}^2}{2g}$$

$$V_{30} = 28.5 \Rightarrow Q = 28.5(4.909) = 140 > 63 \therefore \text{OK}$$

THIS IS TOO MUCH EXCESS CAPACITY - TRY 24" SLOPE PIPE

Dept. \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

ER No. \_\_\_\_\_

Date \_\_\_\_\_ 19 \_\_\_\_\_

Designed by WJB

PROJECT \_\_\_\_\_

Sht. No. 13 of 22

Approved by \_\_\_\_\_

ASSUME 36"  $\phi$  INLET; 24"  $\phi$  SLOPE PIPE

$$Q_{36} = Q_{24}$$

$$V_{36} A_{36} = V_{24} A_{24}$$

$$V_{36} (7.069) = V_{24} (3.142)$$

$$V_{36} = .444 V_{24}$$

BERNOULLI Eq: ①  $\rightarrow$  ③

$$\frac{V_1^2}{2g} + \frac{P_1}{\gamma} + Z_1 = \frac{V_2^2}{2g} + \frac{P_2}{\gamma} + Z_2 + \sum h_p$$

$$561.4 = \frac{V_{24}^2}{2g} + 529 + h_m + h_f$$

MINOR LOSSES:

$$\text{ENTRANCE} = \frac{.5 V_{36}^2}{2g} \equiv \frac{.10 V_{24}^2}{2g}$$

$$\text{1ST BEND} = \frac{.17 V_{36}^2}{2g} \equiv \frac{.03 V_{24}^2}{2g}$$

$$\text{CONTRACTION} = \frac{.22 V_{24}^2}{2g}$$

$$3 \text{ BENDS} = 3 \left( \frac{.17 V_{24}^2}{2g} \right) = \frac{.51 V_{24}^2}{2g}$$

$$\frac{.86 V_{24}^2}{2g}$$

Dept. \_\_\_\_\_  
Date \_\_\_\_\_ 19\_\_\_\_  
Designed by WJB  
Approved by \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

PROJECT \_\_\_\_\_  
\_\_\_\_\_

ER No. \_\_\_\_\_  
Sht. No. 14 of 22

FRICITION LOSSES:

Assuming  $Q = 63 \text{ cfs}$  ; USING ASCE SEWER DESIGN MANUAL

$$h_{f_{36}} = \frac{2.5}{1000} \times 30 = .75$$

$$h_{f_{24}} = \frac{150}{1000} \times 132 = \frac{19.8}{20.55}$$

$$\therefore 561.4 = \frac{V_{24}^2}{2g} + 529 + \frac{.06 V_{24}^2}{2g} + 20.55$$

$$11.85 = 1.06 \frac{V_{24}^2}{2g}$$

$$V_{24} = 20.26 \quad \therefore Q = 20.26(3.142) = 63.6 > 63 \therefore \text{OK}$$

ALTHOUGH THE CAPACITY IS CLOSE, THIS WILL WORK  
OK SINCE THE QUANTITY OF RUNOFF IS CONSERVATIVE  
AND THE AREA WILL BE OPEN ONLY A FEW YEARS.

Dept. \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

ER No. \_\_\_\_\_

Date \_\_\_\_\_ 19\_\_\_\_

Designed by WJB

PROJECT \_\_\_\_\_

Sht. No. 15 of 22


Approved by \_\_\_\_\_

CHECK LEVEL III BENCH DITCH -

CRITICAL DITCH HAS  $S = .0086$   $d_{max} = 2.0$

CHECK USING DIRTY RUNOFF, SINCE THIS WILL YIELD LARGER  $Q$

Assume  $Q = \frac{1}{2} Q_{max} = \frac{1}{2} (47) = 23.5$  cfs



$n = .023$   $Q = \frac{1.486 A^{5/2} S^{1/2}}{n}$

TRIAL	ASSUMED $d$	$A$	$P$	$r$	$V(f/s)$	$Q(cfs)$
1	1.5	6.75	9.49	.711	4.7	31.7 > 23.5
						$\therefore OK$

NOTE: DITCH WILL FLOW EVEN LESS FULL WHEN LEVEL III IS SEEDED.



Dept. \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

ER No. \_\_\_\_\_

Date \_\_\_\_\_ 19 \_\_\_\_\_

Designed by WJB


PROJECT \_\_\_\_\_

Sht. No. 16 of 22

Approved by \_\_\_\_\_

SIZE LEVEL III SLOPE PIPES -

HEAD WATER DEPTH = 3.  
WHICH IS OK FOR  
INLET CORNER W/36" PIPE



ASSUME 36"  $\phi$  INLET ? 24"  $\phi$  SLOPE PIPE

$$Q_{36} = Q_{24}$$

$$\therefore V_{36} = .444 V_{24}$$

BERNOULLI Eq: ①  $\rightarrow$  ③

$$\frac{V_1^2}{2g} + \frac{P_1}{\gamma} + Z_1 = \frac{V_3^2}{2g} + \frac{P_3}{\gamma} + Z_3 + \sum h_f$$

Dept. \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

ER No. \_\_\_\_\_

Date \_\_\_\_\_ 19\_\_\_\_

Designed by WJB

PROJECT \_\_\_\_\_

Sht. No. 17 of 22

Approved by \_\_\_\_\_

$$583 = \frac{V_{24}^2}{2g} + 528 + h_m + h_f$$

MINOR LOSSES:

$$\text{ENTRANCE} = \frac{.5 V_{36}^2}{2g} = \frac{.10 V_{24}^2}{2g}$$

$$1^{\text{ST}} \text{ BEND} = \frac{.17 V_{36}^2}{2g} = \frac{.03 V_{24}^2}{2g}$$

$$\text{CONTRACTION} = \frac{.22 V_{24}^2}{2g}$$

$$5 \text{ BENDS} = 5 \left( \frac{.17 V_{24}^2}{2g} \right) = \frac{.85 V_{24}^2}{2g}$$

$$\frac{1.2 V_{24}^2}{2g}$$

FRICTION LOSSES:

ASSUMING  $Q = 47 \text{ cfs}$

$$h_{f_{36}} = \frac{14}{1000} \times 30 = .42$$

$$h_{f_{24}} = \frac{95}{1000} \times 229 = \frac{21.76}{22.18}$$

$$583 = \frac{V_{24}^2}{2g} + 528 + \frac{1.2 V_{24}^2}{2g} + 22.18$$

$$32.82 = \frac{2.2 V_{24}^2}{2g}$$

$$V_{24} = 30.99$$

$$Q = 30.99(3.142) = 97 \text{ cfs} > 47 \therefore \text{OK}$$

Dept. \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

ER No. \_\_\_\_\_

Date \_\_\_\_\_ 19 \_\_\_\_\_

Designed by UJB

PROJECT \_\_\_\_\_

Sht. No. 18 of 22

Approved by \_\_\_\_\_

REVISED SFR FOR Q<sub>25</sub>SOUTH WEST CLEW DITCH - AREA = 25.35 ACRES

$$\text{WEIGHTED S: } \frac{10.7(1) + 3.51(33) + 1.04(1) + 4.2(33) + 1.2(1) + 4.7(33)}{25.35}$$

$$S = 16.6 \quad \text{say } 16\%$$

$$\text{WEIGHTED CN: } \frac{10.7(70) + 3.51(70) + 1.04(90) + 4.2(70) + 1.2(90) + 4.7(70)}{25.35}$$

$$CN = 79$$

DETERMINE PEAK Q:

for steep slope (16%) CN = 75

for steep slope (16%) CN = 80

$$Q_{25} = 77 \text{ CFS}$$

$$Q = 63 \text{ cfs}$$

$$Q_{25} = 90 \text{ CFS}$$

$$Q = 78 \text{ cfs}$$

<u>CN</u>	<u>Q</u>
75	63
79	X
80	78

$$\frac{79-75}{80-75} = \frac{X-63}{78-63}$$

$$X = 75$$

$$\therefore \text{ for } CN = 79 \quad Q = 75 \text{ cfs}$$

$$Q_{25} = 87 \text{ CFS}$$

Dept. \_\_\_\_\_ PENNSYLVANIA POWER & LIGHT COMPANY  
Date \_\_\_\_\_ 19 \_\_\_\_\_ CALCULATION SHEET  
Designed by WJB PROJECT \_\_\_\_\_ ER No. \_\_\_\_\_  
Approved by \_\_\_\_\_ Sht. No. 19 of 22  
JAS REVISED 5/96 FOR Q25

SOUTH EAST CLEAN DITCH — AREA = 24.66 ACRES

$$\text{WEIGHTED } S: \frac{11.24(1) + 3.48(33) + 1.04(1) + 4.10(33) + 1.0(1) + 3.8(33)}{24.66}$$

$$S = 15.8 \text{ say } 16\%$$

$$\text{WEIGHTED } CN: \frac{11.24(70) + 3.48(70) + 1.04(90) + 4.1(70) + 1(90) + 3.8(70)}{24.66}$$


$$CN = 79$$

$$Q_{25} = 87 \text{ CFS}$$

FROM PREVIOUS PAGE  $Q = 75 \text{ cfs}$  for 16% slope;  $CN=79$

CHECK SOUTH DITCH CAPACITY

EAST SIDE



$$S = \frac{522 - 520.46}{19184.4 - 13+50} = .0024 \leftarrow \text{CRITICAL}$$

WEST SIDE

$$S = \frac{522 - 520}{2700 - 2100} = .0033$$


Dept. \_\_\_\_\_  
Date \_\_\_\_\_ 19\_\_\_\_  
Designed by WJB  
Approved by \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

PROJECT \_\_\_\_\_

ER No. \_\_\_\_\_

Sht. No. 20 of 22



$S = .0024$   
 $n = .023$  (EARTH CHANNEL)

$$Q = 1.486 A^{5/2} S^{1/2}$$

TRIAL	ASSUMED $d$	$A$	$P$	$R$	$V$	$Q$
1	2	16.0	12.94	1.24	3.6	57.6 cfs
2	2.5	22.5	15.18	1.48	4.1	92.25 cfs

$$Q = (K'/n) b^{2/3} S^{1/2}$$

$$75 = (K'/.023) (4)^{2/3} (.0024)^{1/2}$$

$$K' = .073$$

.35      .826  
x      .873  
.60      .990

$$\frac{x-.55}{.05} = \frac{.047}{.164}$$

$$x = .564$$

$$y/b = .564 \Rightarrow y = 2.26'$$

Dept. \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

ER No. \_\_\_\_\_

Date \_\_\_\_\_ 19 \_\_\_\_\_

Designed by WJB

PROJECT \_\_\_\_\_

Sht. No. 21 of 22

Approved by \_\_\_\_\_

JAS REVISED 5/96 FOR Q<sub>25</sub>

CLEAN RUNOFF CULVERTS

AREA = 50.01 ACRES

$$\text{WEIGHTED S: } \frac{1(10.7 + 11.24 + 1.04 + 1.04 + 1.2 + 1.0) + 33(3.51 + 3.48 + 4.2 + 4.1 + 4.7 + 3.8)}{50.01}$$

$$S = 16.22 \text{ say } 16\%$$

$$\text{WEIGHTED CN: } \frac{78(10.70 + 11.24 + 3.51 + 3.48 + 4.2 + 4.1 + 4.7 + 3.8) + 90(1.04 + 1.04 + 1.2 + 1.0)}{50.01}$$

CN: 79

for steep slope (16%) CN 75

for steep slope (16%) CN 80

$$Q_{25} = 135 \text{ CFS}$$

$$Q = 110 \text{ cfs}$$

$$Q_{25} = 170 \text{ CFS}$$

$$Q = 150 \text{ cfs}$$

for S = 16% CN 79

75      110

79      Q

80      150

$$\frac{79-75}{80-75} = \frac{Q-110}{150-110}$$

$$\rightarrow Q = 142 \text{ cfs}$$

$$Q_{25} = 163 \text{ CFS}$$



Dept. \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

ER No. \_\_\_\_\_

Date \_\_\_\_\_ 19 \_\_\_\_\_

Designed by WJB

PROJECT \_\_\_\_\_

Sht. No. 22 of 22

Approved by \_\_\_\_\_

DETERMINE DESIGN  $Q$  FOR CLEAN RUNOFF CULVERTS  
FOR THE STORMS SHOWN

$$S = 16\% \quad A = 50.01 \text{ Ac.}$$

STORM	$i$	$Q$ CN 75	$Q$ CN 80	$Q$ CN 79	
5yr - 24hr.	3.75	75	110	103	
10yr - 24hr.	4.5	110	150	142	
25yr - 24hr.	5.0	138	180	172	
50yr - 24hr.	5.5	160	205	196	
100yr - 24hr.	6.3	210	255	246	

1/8

MONTAUR ASH AREA NO.3  
EVALUATE EXISTING DITCHES FOR Q<sub>25</sub>  
Trapezoidal Channel Analysis & Design  
Open Channel - Uniform flow

Worksheet Name: SW Dirty Base Ditch

JAS 5/96

Comment: Concrete Lined, with freeboard

Solve For Depth

Given Input Data:

Bottom Width.....	4.00 ft
Left Side Slope..	2.00:1 (H:V)
Right Side Slope.	2.00:1 (H:V)
Manning's n.....	0.013
Channel Slope....	0.0028 ft/ft
Discharge.....	135.00 cfs

Computed Results:

Depth.....	2.20 ft
Velocity.....	7.33 fps
Flow Area.....	18.42 sf
Flow Top Width...	12.78 ft
Wetted Perimeter.	13.82 ft
Critical Depth...	2.28 ft
Critical Slope...	0.0024 ft/ft
Froude Number....	1.08 (flow is Supercritical)

2/8

MONTAUR ASH AREA NO. 3  
EVALUATE EXISTING DITCHES FOR Q<sub>25</sub>  
Trapezoidal Channel Analysis & Design  
Open Channel - Uniform flow

Worksheet Name: SW Dirty Base Ditch

JAB 5/96

Comment: Concrete Lined, No freeboard

Solve For Discharge

Given Input Data:

Bottom Width.....	4.00 ft
Left Side Slope..	2.00:1 (H:V)
Right Side Slope.	2.00:1 (H:V)
Manning's n.....	0.013
Channel Slope....	0.0028 ft/ft
Depth.....	3.00 ft

Computed Results:

Discharge.....	260.75 cfs
Velocity.....	8.69 fps
Flow Area.....	30.00 sf
Flow Top Width...	16.00 ft
Wetted Perimeter.	17.42 ft
Critical Depth...	3.17 ft
Critical Slope...	0.0022 ft/ft
Froude Number....	1.12 (flow is Supercritical)

3/8

MONTOUR ASH AREA NO.3  
EVALUATE EXISTING DITCHES FOR Q95  
Trapezoidal Channel Analysis & Design  
Open Channel - Uniform flow

Worksheet Name: SW Clean Base Ditch

JAS 5/96

Comment: Grassed WITH FREEBOARD

Solve For Depth

Given Input Data:

Bottom Width.....	4.00 ft
Left Side Slope..	2.00:1 (H:V)
Right Side Slope.	2.00:1 (H:V)
Manning's n.....	0.027
Channel Slope....	0.0037 ft/ft
Discharge.....	87.00 cfs

Computed Results:

Depth.....	2.36 ft
Velocity.....	4.22 fps
Flow Area.....	20.62 sf
Flow Top Width...	13.45 ft
Wetted Perimeter.	14.57 ft
Critical Depth...	1.81 ft
Critical Slope...	0.0109 ft/ft
Froude Number....	0.60 (flow is Subcritical)

4/8

MONTAUA ASH AREA NO. 3  
EVALUATE EXISTING DITCHES FOR Q25  
Trapezoidal Channel Analysis & Design  
Open Channel - Uniform flow

Worksheet Name: SW Clean Base Ditch

JAB 5/96

Comment: Grassed , NO FREEBOARD

Solve For Discharge

Given Input Data:

Bottom Width.....	4.00 ft
Left Side Slope..	2.00:1 (H:V)
Right Side Slope.	2.00:1 (H:V)
Manning's n.....	0.027
Channel Slope....	0.0037 ft/ft
Depth.....	3.00 ft

Computed Results:

Discharge.....	144.32 cfs
Velocity.....	4.81 fps
Flow Area.....	30.00 sf
Flow Top Width...	16.00 ft
Wetted Perimeter.	17.42 ft
Critical Depth...	2.36 ft
Critical Slope...	0.0103 ft/ft
Froude Number....	0.62 (flow is Subcritical)

5/8

MONTAUR ASH AREA NO. 3  
EVALUATE EXISTING DITCHES FOR Q<sub>50</sub>  
Triangular Channel Analysis & Design  
Open Channel - Uniform flow

Worksheet Name: Bench ditch

JAS 5/96

Comment: Lined with shale, WITH FREEBOARD

Solve For Depth

Given Input Data:

Left Side Slope..	3.00:1 (H:V)
Right Side Slope.	3.00:1 (H:V)
Manning's n.....	0.025
Channel Slope....	0.0047 ft/ft
Discharge.....	25.00 cfs

Computed Results:

Depth.....	1.58 ft
Velocity.....	3.36 fps
Flow Area.....	7.45 sf
Flow Top Width...	9.45 ft
Wetted Perimeter.	9.97 ft
Critical Depth...	1.34 ft
Critical Slope...	0.0112 ft/ft
Froude Number....	0.67 (flow is Subcritical)



6/8

MONTGOMERY ASH AREA NO. 3  
EVALUATE EXISTING DITCHES FOR Q25  
Triangular Channel Analysis & Design  
Open Channel - Uniform flow

Worksheet Name: Bench ditch

JAB 5/94

Comment: Lined with shale, NO FREEBOARD

Solve For Discharge

Given Input Data:

Left Side Slope..	3.00:1 (H:V)
Right Side Slope.	3.00:1 (H:V)
Manning's n.....	0.025
Channel Slope....	0.0047 ft/ft
Depth.....	2.50 ft

Computed Results:

Discharge.....	85.60 cfs
Velocity.....	4.57 fps
Flow Area.....	18.75 sf
Flow Top Width...	15.00 ft
Wetted Perimeter.	15.81 ft
Critical Depth...	2.19 ft
Critical Slope...	0.0095 ft/ft
Froude Number....	0.72 (flow is Subcritical)

7/8

MONTAUK ASH AREA NO. 3  
EVALUATE EXISTING DITCHES FOR Q25  
Trapezoidal Channel Analysis & Design  
Open Channel - Uniform flow

Worksheet Name: Ditch to Stream JAB 5/96

Comment: Riprap , WITH FREEBOARD

Solve For Depth

Given Input Data:

Bottom Width.....	16.00 ft
Left Side Slope..	2.00:1 (H:V)
Right Side Slope.	2.00:1 (H:V)
Manning's n.....	0.030
Channel Slope....	0.0010 ft/ft
Discharge.....	322.00 cfs

Computed Results:

Depth.....	4.15 ft
Velocity.....	3.20 fps
Flow Area.....	100.72 sf
Flow Top Width...	32.58 ft
Wetted Perimeter.	34.54 ft
Critical Depth...	2.12 ft
Critical Slope...	0.0115 ft/ft
Froude Number....	0.32 (flow is Subcritical)

8/8

MONTGOMERY ASH AREA NO. 3  
EVALUATE EXISTING DITCHES FOR Q<sub>25</sub>  
Trapezoidal Channel Analysis & Design  
Open Channel - Uniform flow

Worksheet Name: Ditch to Stream JAB 5/96

Comment: Riprap , NO FREEBOARD

Solve For Discharge

Given Input Data:

Bottom Width.....	16.00 ft
Left Side Slope..	2.00:1 (H:V)
Right Side Slope.	2.00:1 (H:V)
Manning's n.....	0.030
Channel Slope....	0.0010 ft/ft
Depth.....	4.50 ft

Computed Results:

Discharge.....	375.79 cfs
Velocity.....	3.34 fps
Flow Area.....	112.50 sf
Flow Top Width...	34.00 ft
Wetted Perimeter.	36.12 ft
Critical Depth...	2.33 ft
Critical Slope...	0.0112 ft/ft
Froude Number....	0.32 (flow is Subcritical)



## **Stormwater Routing Calculations**

**Application for Residual Waste Minor Permit Modification**

**Storm Routing Calculations**

**Pennsylvania Power and Light Company  
Montour Steam Electric Station  
Ash Area No. 3 Leachate Runoff Basin**



POND-2 Version: 5.17 S/N:  
EXECUTED: 06-08-1995 12:54:52

STORM ROUTING  
w/ PUMPS

Page 1  
Return Freq: 25 years

\*\*\*\*\*  
\*  
\* Multiple Storms Routed thru Leachate/Runoff Basin \*  
\* Ponding Behind L/R Basin Inlet Culvert \*  
\* Pumps in Operation: 2700 GPM at el 517.00, 4500 GPM at el. 520.0 \*  
\* = 6 cfs = 10 cfs \*  
\*\*\*\*\*

Inflow Hydrograph: AB25YRIN.HYD  
Rating Table file: PUMPS-ON.PND

----INITIAL CONDITIONS----

Elevation = 517.00 ft  
Outflow = 6.00 cfs  
Storage = 0.58 ac-ft

GIVEN POND DATA

ELEVATION (ft)	OUTFLOW (cfs)	STORAGE (ac-ft)
517.00	6.0	0.577
517.33	6.0	0.989
517.67	6.0	1.423
518.00	6.0	1.880
518.33	6.0	2.364
518.67	6.0	2.880
519.00	6.0	3.429
519.33	6.0	4.012
519.66	6.0	4.629
520.00	6.0	5.282
520.33	6.0	5.969
520.66	6.0	6.688
521.00	8.4	7.438
521.33	10.0	8.221
521.66	10.0	9.038
522.00	10.0	9.889
522.33	19.4	10.796
522.66	37.7	11.785
522.99	62.4	12.860
523.33	93.1	14.024
523.66	129.3	15.280
523.99	171.0	16.633
524.00	171.9	16.663

INTERMEDIATE ROUTING  
COMPUTATIONS

2S/t (cfs)	2S/t + 0 (cfs)
139.7	145.7
239.4	245.4
344.4	350.4
455.0	461.0
572.1	578.1
697.0	703.0
829.8	835.8
970.8	976.8
1120.3	1126.3
1278.3	1284.3
1444.6	1450.6
1618.5	1624.5
1800.0	1808.4
1989.6	1999.6
2187.2	2197.2
2393.1	2403.1
2612.7	2632.1
2852.1	2889.8
3112.2	3174.6
3393.8	3486.9
3697.9	3827.2
4025.2	4196.2
4032.4	4204.3

Time increment (t) = 0.100 hrs.

POND-2 Version: 5.17 S/N:  
EXECUTED: 06-08-1995 12:54:52

Page 2  
Return Freq: 25 years

\*\*\*\*\* SUMMARY OF ROUTING COMPUTATIONS \*\*\*\*\*

Pond File: PUMPS-ON.PND  
Inflow Hydrograph: AB25YRIN.HYD  
Outflow Hydrograph: AB25PUMP.HYD

Starting Pond W.S. Elevation = 517.00 ft

\*\*\*\*\* Summary of Peak Outflow and Peak Elevation \*\*\*\*\*

Peak Inflow	=	148.00 cfs	
Peak Outflow	=	6.00 cfs	PUMPS (NO OVERFLOW)
Peak Elevation	=	520.63 ft	

\*\*\*\*\* Summary of Approximate Peak Storage \*\*\*\*\*

Initial Storage	=	0.58 ac-ft
Peak Storage From Storm	=	6.05 ac-ft
		-----
Total Storage in Pond	=	6.62 ac-ft

Warning: Inflow hydrograph truncated on left side.

>>>>> Warning, initial pond outflow > 1st inflow ordinate. <<<<<

>>>>>> Warning, peak outflow = last ordinate point. <<<<<<

>>>>> Warning, peak outflow = last ordinate point. <<<<<<  
POND-2 Version: 5.17 S/N:


Page 3

Return Freq: 25 years

Pond File: PUMPS-ON.PND  
Inflow Hydrograph: AB25YRIN.HYD  
Outflow Hydrograph: AB25PUMP.HYD

EXECUTED: 06-08-1995  
12:54:52

Peak Inflow = 148.00 cfs  
Peak Outflow = 6.00 cfs  
Peak Elevation = 520.63 ft



\* FILE: AB25YRIN.HYD QMAX = 148.0 cfs  
X FILE: AB25PUMP.HYD QMAX = 6.0 cfs

POND-2 Version: 5.17 S/N:  
EXECUTED: 06-08-1995 12:54:52

Page 1  
Return Freq: 50 years

\*\*\*\*\*  
\*  
\* Multiple Storms Routed thru Leachate/Runoff Basin \*  
\* Ponding Behind L/R Basin Inlet Culvert \*  
\* Pumps in Operation: 2700 GPM at el 517.00, 4500 GPM at el. 520.0 \*  
\*  
\*  
\*\*\*\*\*

Inflow Hydrograph: AB50YRIN.HYD  
Rating Table file: PUMPS-ON.PND

-----INITIAL CONDITIONS-----  
Elevation = 517.00 ft  
Outflow = 6.00 cfs  
Storage = 0.58 ac-ft

GIVEN POND DATA

ELEVATION (ft)	OUTFLOW (cfs)	STORAGE (ac-ft)
517.00	6.0	0.577
517.33	6.0	0.989
517.67	6.0	1.423
518.00	6.0	1.880
518.33	6.0	2.364
518.67	6.0	2.880
519.00	6.0	3.429
519.33	6.0	4.012
519.66	6.0	4.629
520.00	6.0	5.282
520.33	6.0	5.969
520.66	6.0	6.688
521.00	8.4	7.438
521.33	10.0	8.221
521.66	10.0	9.038
522.00	10.0	9.889
522.33	19.4	10.796
522.66	37.7	11.785
522.99	62.4	12.860
523.33	93.1	14.024
523.66	129.3	15.280
523.99	171.0	16.633
524.00	171.9	16.663

INTERMEDIATE ROUTING  
COMPUTATIONS

2S/t (cfs)	2S/t + 0 (cfs)
139.7	145.7
239.4	245.4
344.4	350.4
455.0	461.0
572.1	578.1
697.0	703.0
829.8	835.8
970.8	976.8
1120.3	1126.3
1278.3	1284.3
1444.6	1450.6
1618.5	1624.5
1800.0	1808.4
1989.6	1999.6
2187.2	2197.2
2393.1	2403.1
2612.7	2632.1
2852.1	2889.8
3112.2	3174.6
3393.8	3486.9
3697.9	3827.2
4025.2	4196.2
4032.4	4204.3

Time increment (t) = 0.100 hrs.

POND-2 Version: 5.17 S/N:  
EXECUTED: 06-08-1995 12:54:52

STORM ROUTING 5/9  
W/ PUMPS  
Page 2  
Return Freq: 50 years

\*\*\*\*\* SUMMARY OF ROUTING COMPUTATIONS \*\*\*\*\*

Pond File: PUMPS-ON.PND  
Inflow Hydrograph: AB50YRIN.HYD  
Outflow Hydrograph: AB50PUMP.HYD

Starting Pond W.S. Elevation = 517.00 ft

\*\*\*\*\* Summary of Peak Outflow and Peak Elevation \*\*\*\*\*

Peak Inflow	=	167.00 cfs	
Peak Outflow	=	8.21 cfs	PUMPS (NO OVEFLOW)
Peak Elevation	=	520.97 ft	

\*\*\*\*\* Summary of Approximate Peak Storage \*\*\*\*\*

Initial Storage	=	0.58 ac-ft
Peak Storage From Storm	=	6.80 ac-ft
		-----
Total Storage in Pond	=	7.38 ac-ft

Warning: Inflow hydrograph truncated on left side.

>>>> Warning, initial pond outflow > 1st inflow ordinate. <<<<

STORM ROUTING 4/9  
w/ PUMPS


POND-2 Version: 5.17 S/N:

Page 3  
Return Freq: 50 years

Pond File: PUMPS-ON.PND  
Inflow Hydrograph: AB50YRIN.HYD  
Outflow Hydrograph: AB50PUMP.HYD

EXECUTED: 06-08-1995  
12:54:52

Peak Inflow = 167.00 cfs  
Peak Outflow = 8.21 cfs  
Peak Elevation = 520.97 ft



\* File: AB50YRIN.HYD Qmax = 167.0 cfs  
x File: AB50PUMP.HYD Qmax = 8.2 cfs



STORM ROUTING 7/9  
w/ PUMPS

POND-2 Version: 5.17 S/N:  
EXECUTED: 06-08-1995 12:54:52

Page 1  
Return Freq: 100 years

\*\*\*\*\*  
\*  
\* Multiple Storms Routed thru Leachate/Runoff Basin \*  
\* Ponding Behind L/R Basin Inlet Culvert \*  
\* Pumps in Operation: 2700 GPM at el 517.00, 4500 GPM at el. 520.0 \*  
\*  
\*  
\*\*\*\*\*

Inflow Hydrograph: AB100YIN.HYD  
Rating Table file: PUMPS-ON.PND

-----INITIAL CONDITIONS-----

Elevation = 517.00 ft  
Outflow = 6.00 cfs  
Storage = 0.58 ac-ft

GIVEN POND DATA

ELEVATION (ft)	OUTFLOW (cfs)	STORAGE (ac-ft)
517.00	6.0	0.577
517.33	6.0	0.989
517.67	6.0	1.423
518.00	6.0	1.880
518.33	6.0	2.364
518.67	6.0	2.880
519.00	6.0	3.429
519.33	6.0	4.012
519.66	6.0	4.629
520.00	6.0	5.282
520.33	6.0	5.969
520.66	6.0	6.688
521.00	8.4	7.438
521.33	10.0	8.221
521.66	10.0	9.038
522.00	10.0	9.889
522.33	19.4	10.796
522.66	37.7	11.785
522.99	62.4	12.860
523.33	93.1	14.024
523.66	129.3	15.280
523.99	171.0	16.633
524.00	171.9	16.663

INTERMEDIATE ROUTING  
COMPUTATIONS

2S/t (cfs)	2S/t + 0 (cfs)
139.7	145.7
239.4	245.4
344.4	350.4
455.0	461.0
572.1	578.1
697.0	703.0
829.8	835.8
970.8	976.8
1120.3	1126.3
1278.3	1284.3
1444.6	1450.6
1618.5	1624.5
1800.0	1808.4
1989.6	1999.6
2187.2	2197.2
2393.1	2403.1
2612.7	2632.1
2852.1	2889.8
3112.2	3174.6
3393.8	3486.9
3697.9	3827.2
4025.2	4196.2
4032.4	4204.3

Time increment (t) = 0.100 hrs.

STORM ROUTING 8/9  
w/ PUMPS

POND-2 Version: 5.17 S/N:  
EXECUTED: 06-08-1995 12:54:52

Page 2  
Return Freq: 100 years

\*\*\*\*\* SUMMARY OF ROUTING COMPUTATIONS \*\*\*\*\*

Pond File: PUMPS-ON.PND  
Inflow Hydrograph: AB100YIN.HYD  
Outflow Hydrograph: AB100PUM.HYD

Starting Pond W.S. Elevation = 517.00 ft

\*\*\*\*\* Summary of Peak Outflow and Peak Elevation \*\*\*\*\*

Peak Inflow	=	199.00 cfs	
Peak Outflow	=	10.00 cfs	PUMPS (NO OVERFLOW)
Peak Elevation	=	521.50 ft	

\*\*\*\*\* Summary of Approximate Peak Storage \*\*\*\*\*

Initial Storage	=	0.58 ac-ft
Peak Storage From Storm	=	8.06 ac-ft
		-----
Total Storage in Pond	=	8.64 ac-ft

Warning: Inflow hydrograph truncated on left side.

STORM NOUING 9/9  
w/ PUMPS


POND-2 Version: 5.17 S/N:

Page 3  
Return Freq: 100 years

Pond File: PUMPS-ON.PND  
Inflow Hydrograph: AB100YIN.HYD  
Outflow Hydrograph: AB100PUM.HYD

EXECUTED: 06-08-1995  
12:54:52

Peak Inflow = 199.00 cfs  
Peak Outflow = 10.00 cfs  
Peak Elevation = 521.50 ft



\* File: AB100YIN.HYD Qmax = 199.0 cfs  
x File: AB100PUM.HYD Qmax = 10.0 cfs

STORM ROUTING  
WO/PUMPS

1/9

POND-2 Version: 5.17 S/N:  
EXECUTED: 06-08-1995 12:33:36

Page 1  
Return Freq: 25 years

\*\*\*\*\*  
\*  
\* Multiple Storms Routed thru Leachate/Runoff Basin \*  
\* Ponding Behind L/R Basin Inlet Culvert Included in Basin Capacit \*  
\* PUMP FAILURE \*  
\*  
\*  
\*\*\*\*\*

Inflow Hydrograph: AB25YRIN.HYD  
Rating Table file: TRAP16 .PND

-----INITIAL CONDITIONS-----  
Elevation = 522.00 ft  
Outflow = 0.00 cfs  
Storage = 9.90 ac-ft

GIVEN POND DATA

ELEVATION (ft)	OUTFLOW (cfs)	STORAGE (ac-ft)
522.00	0.0	9.902
522.25	6.2	10.576
522.50	18.0	11.297
522.75	33.7	12.064
523.00	52.9	12.880
523.25	75.5	13.747
523.50	101.2	14.665
523.75	130.0	15.637
524.00	161.9	16.663

INTERMEDIATE ROUTING  
COMPUTATIONS

2S/t (cfs)	2S/t + 0 (cfs)
2396.2	2396.2
2559.5	2565.7
2733.8	2751.8
2919.5	2953.2
3117.0	3169.9
3326.7	3402.2
3548.9	3650.1
3784.0	3914.0
4032.4	4194.3

Time increment (t) = 0.100 hrs.

STORM ROUTING  
WO/PUMPS 2/9

POND-2 Version: 5.17 S/N:  
EXECUTED: 06-08-1995 12:33:36

Page 2  
Return Freq: 25 years

\*\*\*\*\* SUMMARY OF ROUTING COMPUTATIONS \*\*\*\*\*

Pond File: TRAP16 .PND  
Inflow Hydrograph: AB25YRIN.HYD  
Outflow Hydrograph: 25TRAPOU.HYD

Starting Pond W.S. Elevation = 522.00 ft

\*\*\*\*\* Summary of Peak Outflow and Peak Elevation \*\*\*\*\*

Peak Inflow	=	148.00 cfs
Peak Outflow	=	64.71 cfs
Peak Elevation	=	523.13 ft

\*\*\*\*\* Summary of Approximate Peak Storage \*\*\*\*\*

Initial Storage	=	9.90 ac-ft
Peak Storage From Storm	=	3.43 ac-ft
		-----
Total Storage in Pond	=	13.33 ac-ft

Warning: Inflow hydrograph truncated on left side.


POND-2 Version: 5.17 S/N:

Page 3  
Return Freq: 25 years

Pond File: TRAP16 .PND  
Inflow Hydrograph: AB25YRIN.HYD  
Outflow Hydrograph: 25TRAPOU.HYD

EXECUTED: 06-08-1995  
12:33:36

Peak Inflow = 148.00 cfs  
Peak Outflow = 64.71 cfs  
Peak Elevation = 523.13 ft



\* File: AB25YRIN.HYD Qmax = 148.0 cfs  
x File: 25TRAPOU.HYD Qmax = 64.7 cfs



POND-2 Version: 5.17 S/N:  
EXECUTED: 06-08-1995 12:33:36

Page 1  
Return Freq: 50 years

\*\*\*\*\*  
\*  
\* Multiple Storms Routed thru Leachate/Runoff Basin \*  
\* Ponding Behind L/R Basin Inlet Culvert Included in Basin Capacit \*  
\* PUMP FAILURE \*  
\*  
\*  
\*\*\*\*\*

Inflow Hydrograph: AB50YRIN.HYD  
Rating Table file: TRAP16 .PND

----INITIAL CONDITIONS----  
Elevation = 522.00 ft  
Outflow = 0.00 cfs  
Storage = 9.90 ac-ft

GIVEN POND DATA

ELEVATION (ft)	OUTFLOW (cfs)	STORAGE (ac-ft)
522.00	0.0	9.902
522.25	6.2	10.576
522.50	18.0	11.297
522.75	33.7	12.064
523.00	52.9	12.880
523.25	75.5	13.747
523.50	101.2	14.665
523.75	130.0	15.637
524.00	161.9	16.663

INTERMEDIATE ROUTING  
COMPUTATIONS

2S/t (cfs)	2S/t + 0 (cfs)
2396.2	2396.2
2559.5	2565.7
2733.8	2751.8
2919.5	2953.2
3117.0	3169.9
3326.7	3402.2
3548.9	3650.1
3784.0	3914.0
4032.4	4194.3

Time increment (t) = 0.100 hrs.

STORM ROUTING 5/9  
WO/PUMPS

POND-2 Version: 5.17 S/N:  
EXECUTED: 06-08-1995 12:33:36

Page 2  
Return Freq: 50 years

\*\*\*\*\* SUMMARY OF ROUTING COMPUTATIONS \*\*\*\*\*

Pond File: TRAP16 .PND  
Inflow Hydrograph: AB50YRIN.HYD  
Outflow Hydrograph: 50TRAPOU.HYD

Starting Pond W.S. Elevation = 522.00 ft

\*\*\*\*\* Summary of Peak Outflow and Peak Elevation \*\*\*\*\*

Peak Inflow	=	167.00 cfs
Peak Outflow	=	74.82 cfs
Peak Elevation	=	523.24 ft

\*\*\*\*\* Summary of Approximate Peak Storage \*\*\*\*\*

Initial Storage	=	9.90 ac-ft
Peak Storage From Storm	=	3.82 ac-ft
		-----
Total Storage in Pond	=	13.72 ac-ft

Warning: Inflow hydrograph truncated on left side.

STORM ROUTING  
WO/PUMPS 6/9


POND-2 Version: 5.17 S/N:

Page 3  
Return Freq: 50 years

Pond File: TRAP16 .PND  
Inflow Hydrograph: AB50YRIN.HYD  
Outflow Hydrograph: 50TRAPOU.HYD

EXECUTED: 06-08-1995  
12:33:36

Peak Inflow = 167.00 cfs  
Peak Outflow = 74.82 cfs  
Peak Elevation = 523.24 ft



\* File: AB50YRIN.HYD Qmax = 167.0 cfs  
x File: 50TRAPOU.HYD Qmax = 74.8 cfs

POND-2 Version: 5.17 S/N:  
EXECUTED: 06-08-1995 12:33:36

Page 1  
Return Freq: 100 years

\*\*\*\*\*  
\*  
\* Multiple Storms Routed thru Leachate/Runoff Basin \*  
\* Ponding Behind L/R Basin Inlet Culvert Included in Basin Capacit \*  
\* PUMP FAILURE \*  
\*  
\*\*\*\*\*

Inflow Hydrograph: AB100YIN.HYD  
Rating Table file: TRAP16 .PND

-----INITIAL CONDITIONS-----

Elevation = 522.00 ft  
Outflow = 0.00 cfs  
Storage = 9.90 ac-ft

GIVEN POND DATA

ELEVATION (ft)	OUTFLOW (cfs)	STORAGE (ac-ft)
522.00	0.0	9.902
522.25	6.2	10.576
522.50	18.0	11.297
522.75	33.7	12.064
523.00	52.9	12.880
523.25	75.5	13.747
523.50	101.2	14.665
523.75	130.0	15.637
524.00	161.9	16.663

INTERMEDIATE ROUTING  
COMPUTATIONS

2S/t (cfs)	2S/t + 0 (cfs)
2396.2	2396.2
2559.5	2565.7
2733.8	2751.8
2919.5	2953.2
3117.0	3169.9
3326.7	3402.2
3548.9	3650.1
3784.0	3914.0
4032.4	4194.3

Time increment (t) = 0.100 hrs.

POND-2 Version: 5.17 S/N:  
EXECUTED: 06-08-1995 12:33:36

STORM ROUTING  
WO/PUMPS 8/9  
Page 2  
Return Freq: 100 years

\*\*\*\*\* SUMMARY OF ROUTING COMPUTATIONS \*\*\*\*\*

Pond File: TRAP16 .PND  
Inflow Hydrograph: AB100YIN.HYD  
Outflow Hydrograph: 100TRAPO.HYD

Starting Pond W.S. Elevation = 522.00 ft

\*\*\*\*\* Summary of Peak Outflow and Peak Elevation \*\*\*\*\*

Peak Inflow = 199.00 cfs  
Peak Outflow = 92.41 cfs  
Peak Elevation = 523.41 ft

\*\*\*\*\* Summary of Approximate Peak Storage \*\*\*\*\*

Initial Storage = 9.90 ac-ft  
Peak Storage From Storm = 4.45 ac-ft  
-----  
Total Storage in Pond = 14.35 ac-ft

Warning: Inflow hydrograph truncated on left side.

STORM ROUTING  
WO/PUMPS 9/9


POND-2 Version: 5.17 S/N:

Page 3  
Return Freq: 100 years

Pond File: TRAP16 .PND  
Inflow Hydrograph: AB100YIN.HYD  
Outflow Hydrograph: 100TRAPO.HYD

EXECUTED: 06-08-1995  
12:33:36

Peak Inflow = 199.00 cfs  
Peak Outflow = 92.41 cfs  
Peak Elevation = 523.41 ft



\* File: AB100YIN.HYD Qmax = 199.0 cfs  
x File: 100TRAPO.HYD Qmax = 92.4 cfs

Quick TR-55 Version: 5.46 S/N:

Page 1

Return Frequency: 25 years

TR-55 TABULAR HYDROGRAPH METHOD  
Type II. Distribution  
(24 hr. Duration Storm)

Executed: 06-08-1995 14:15:41  
Watershed file: --> C:\PONDPACK\ABCELLS .MOP  
Hydrograph file: --> C:\PONDPACK\AB25YR.HYD

A&amp;B Cells Only, C&amp;D Cells Not Developed

## &gt;&gt;&gt;&gt; Input Parameters Used to Compute Hydrograph &lt;&lt;&lt;&lt;

Subarea Description	AREA (acres)	CN	Tc (hrs)	* Tt (hrs)	Precip. (in)	Runoff (in)	Ia/p input/used
Ash Pile Top	22.00	85.0	0.30	0.00	5.00	3.37	I.07 .10
Pile sides/base	14.00	91.0	0.20	0.00	5.00	3.98	I.04 .10

\* Travel time from subarea outfall to composite watershed outfall point.  
I -- Subarea where user specified interpolation between Ia/p tables.

Total area = 36.00 acres or 0.05625 sq.mi  
Peak discharge = 148 cfs

## &gt;&gt;&gt;&gt; Computer Modifications of Input Parameters &lt;&lt;&lt;&lt;

Subarea Description	Input Values		Rounded Values		Ia/p Interpolated	Ia/p Messages
	Tc (hr)	* Tt (hr)	Tc (hr)	* Tt (hr)	(Yes/No)	
Ash Pile Top	0.33	0.00	0.30	0.00	No	Computed Ia/p < .1
Pile sides/base	0.20	0.00	**	**	No	Computed Ia/p < .1

\* Travel time from subarea outfall to composite watershed outfall point.  
\*\* Tc & Tt are available in the hydrograph tables.



Quick TR-55 Version: 5.46 S/N:

Page 2

Return Frequency: 25 years

TR-55 TABULAR HYDROGRAPH METHOD  
Type II. Distribution  
(24 hr. Duration Storm)

Executed: 06-08-1995 14:15:41

Watershed file: --&gt; C:\PONDPACK\ABCELLS .MOP

Hydrograph file: --&gt; C:\PONDPACK\AB25YR.HYD

A&amp;B Cells Only, C&amp;D Cells Not Developed

## &gt;&gt;&gt;&gt; Summary of Subarea Times to Peak &lt;&lt;&lt;&lt;

Subarea	Peak Discharge at Composite Outfall (cfs)	Time to Peak at Composite Outfall (hrs)
Ash Pile Top	78	12.2
Pile sides/base	70	12.2
Composite Watershed	148	12.2

Quick TR-55 Version: 5.46 S/N:

Page 3

Return Frequency: 25 years

TR-55 TABULAR HYDROGRAPH METHOD  
Type II. Distribution  
(24 hr. Duration Storm)

Executed: 06-08-1995 14:15:41  
Watershed file: --> C:\PONDPACK\ABCELLS .MOP  
Hydrograph file: --> C:\PONDPACK\AB25YR.HYD

A&amp;B Cells Only, C&amp;D Cells Not Developed

## Composite Hydrograph Summary (cfs)

Subarea Description	11.0 hr	11.3 hr	11.6 hr	11.9 hr	12.0 hr	12.1 hr	12.2 hr	12.3 hr	12.4 hr
Ash Pile Top	2	3	5	14	27	52	78	78	53
Pile sides/base	2	3	4	18	35	64	70	42	22
Total (cfs)	4	6	9	32	62	116	148	120	75

Subarea Description	12.5 hr	12.6 hr	12.7 hr	12.8 hr	13.0 hr	13.2 hr	13.4 hr	13.6 hr	13.8 hr
Ash Pile Top	33	23	17	13	9	8	7	6	5
Pile sides/base	14	11	9	7	6	5	5	4	4
Total (cfs)	47	34	26	20	15	13	12	10	9

Subarea Description	14.0 hr	14.3 hr	14.6 hr	15.0 hr	15.5 hr	16.0 hr	16.5 hr	17.0 hr	17.5 hr
Ash Pile Top	5	4	4	4	3	3	3	2	2
Pile sides/base	3	3	3	3	2	2	2	2	2
Total (cfs)	8	7	7	7	5	5	5	4	4

Subarea Description	18.0 hr	19.0 hr	20.0 hr	22.0 hr	26.0 hr
Ash Pile Top	2	2	2	1	0
Pile sides/base	2	1	1	1	0
Total (cfs)	4	3	3	2	0

Quick TR-55 Version: 5.46 S/N:

Page 1

Return Frequency: 50 years

TR-55 TABULAR HYDROGRAPH METHOD  
Type II. Distribution  
(24 hr. Duration Storm)

Executed: 06-08-1995 14:15:41  
Watershed file: --> C:\PONDPACK\ABCELLS .MOP  
Hydrograph file: --> C:\PONDPACK\AB50YR.HYD

A&amp;B Cells Only, C&amp;D Cells Not Developed

## &gt;&gt;&gt;&gt; Input Parameters Used to Compute Hydrograph &lt;&lt;&lt;&lt;

Subarea Description	AREA (acres)	CN	Tc (hrs)	* Tt (hrs)	Precip. (in)	Runoff (in)	Ia/p input/used
Ash Pile Top	22.00	85.0	0.30	0.00	5.50	3.83	I.06 .10
Pile sides/base	14.00	91.0	0.20	0.00	5.50	4.47	I.04 .10

\* Travel time from subarea outfall to composite watershed outfall point.  
I -- Subarea where user specified interpolation between Ia/p tables.

Total area = 36.00 acres or 0.05625 sq.mi  
Peak discharge = 167 cfs

## &gt;&gt;&gt;&gt; Computer Modifications of Input Parameters &lt;&lt;&lt;&lt;

Subarea Description	Input Values		Rounded Values		Ia/p Interpolated	Ia/p Messages
	Tc (hr)	* Tt (hr)	Tc (hr)	* Tt (hr)	(Yes/No)	
Ash Pile Top	0.33	0.00	0.30	0.00	No	Computed Ia/p < .1
Pile sides/base	0.20	0.00	**	**	No	Computed Ia/p < .1

\* Travel time from subarea outfall to composite watershed outfall point.  
\*\* Tc & Tt are available in the hydrograph tables.

Quick TR-55 Version: 5.46 S/N:

Page 2

Return Frequency: 50 years

TR-55 TABULAR HYDROGRAPH METHOD  
Type II. Distribution  
(24 hr. Duration Storm)

Executed: 06-08-1995 14:15:41  
Watershed file: --> C:\PONDPACK\ABCELLS .MOP  
Hydrograph file: --> C:\PONDPACK\AB50YR.HYD

A&amp;B Cells Only, C&amp;D Cells Not Developed

## &gt;&gt;&gt;&gt; Summary of Subarea Times to Peak &lt;&lt;&lt;&lt;

Subarea	Peak Discharge at Composite Outfall (cfs)	Time to Peak at Composite Outfall (hrs)
Ash Pile Top	89	12.2
Pile sides/base	78	12.2
Composite Watershed	167	12.2

Quick TR-55 Version: 5.46 S/N:

Page 3

Return Frequency: 50 years

TR-55 TABULAR HYDROGRAPH METHOD  
Type II. Distribution  
(24 hr. Duration Storm)

Executed: 06-08-1995 14:15:41  
Watershed file: --> C:\PONDPACK\ABCELLS .MOP  
Hydrograph file: --> C:\PONDPACK\AB50YR.HYD

A&amp;B Cells Only, C&amp;D Cells Not Developed

## Composite Hydrograph Summary (cfs)

Subarea Description	11.0 hr	11.3 hr	11.6 hr	11.9 hr	12.0 hr	12.1 hr	12.2 hr	12.3 hr	12.4 hr
Ash Pile Top	3	4	5	16	31	59	89	89	60
Pile sides/base	2	3	5	20	39	72	78	47	24
Total (cfs)	5	7	10	36	70	131	167	136	84

Subarea Description	12.5 hr	12.6 hr	12.7 hr	12.8 hr	13.0 hr	13.2 hr	13.4 hr	13.6 hr	13.8 hr
Ash Pile Top	37	26	19	15	11	9	8	7	6
Pile sides/base	16	13	10	8	7	6	5	5	4
Total (cfs)	53	39	29	23	18	15	13	12	10

Subarea Description	14.0 hr	14.3 hr	14.6 hr	15.0 hr	15.5 hr	16.0 hr	16.5 hr	17.0 hr	17.5 hr
Ash Pile Top	6	5	4	4	4	3	3	3	3
Pile sides/base	4	3	3	3	3	2	2	2	2
Total (cfs)	10	8	7	7	7	5	5	5	5

Subarea Description	18.0 hr	19.0 hr	20.0 hr	22.0 hr	26.0 hr
Ash Pile Top	2	2	2	2	0
Pile sides/base	2	2	1	1	0

TOTAL (cfs) 4 4 3 3 0

Quick TR-55 Version: 5.46 S/N:

Page 1

Return Frequency: 100 years

## TR-55 TABULAR HYDROGRAPH METHOD

Type II. Distribution

(24 hr. Duration Storm)

Executed: 06-08-1995 14:15:41

Watershed file: --&gt; C:\PONDPACK\ABCELLS .MOP

Hydrograph file: --&gt; C:\PONDPACK\AB100YR.HYD

A&amp;B Cells Only, C&amp;D Cells Not Developed

## &gt;&gt;&gt;&gt; Input Parameters Used to Compute Hydrograph &lt;&lt;&lt;&lt;

Subarea Description	AREA (acres)	CN	Tc (hrs)	* Tt (hrs)	Precip. (in)	Runoff (in)	Ia/p input/used
Ash Pile Top	22.00	85.0	0.30	0.00	6.30	4.59	I.06 .10
Pile sides/base	14.00	91.0	0.20	0.00	6.30	5.25	I.03 .10

\* Travel time from subarea outfall to composite watershed outfall point.

I -- Subarea where user specified interpolation between Ia/p tables.

Total area = 36.00 acres or 0.05625 sq.mi

Peak discharge = 199 cfs

## &gt;&gt;&gt;&gt; Computer Modifications of Input Parameters &lt;&lt;&lt;&lt;

Subarea Description	Input Values		Rounded Values		Ia/p	Ia/p Messages
	Tc (hr)	* Tt (hr)	Tc (hr)	* Tt (hr)	Interpolated (Yes/No)	
Ash Pile Top	0.33	0.00	0.30	0.00	No	Computed Ia/p < .1
Pile sides/base	0.20	0.00	**	**	No	Computed Ia/p < .1

\* Travel time from subarea outfall to composite watershed outfall point.

\*\* Tc &amp; Tt are available in the hydrograph tables.

Quick TR-55 Version: 5.46 S/N:

Page 2  
Return Frequency: 100 yearsTR-55 TABULAR HYDROGRAPH METHOD  
Type II. Distribution  
(24 hr. Duration Storm)Executed: 06-08-1995 14:15:41  
Watershed file: --> C:\PONDPACK\ABCELLS .MOP  
Hydrograph file: --> C:\PONDPACK\AB100YR.HYD

A&amp;B Cells Only, C&amp;D Cells Not Developed

## &gt;&gt;&gt;&gt; Summary of Subarea Times to Peak &lt;&lt;&lt;&lt;

Subarea	Peak Discharge at Composite Outfall (cfs)	Time to Peak at Composite Outfall (hrs)
Ash Pile Top	107	12.2
Pile sides/base	92	12.2
Composite Watershed	199	12.2



TR-55 TABULAR HYDROGRAPH METHOD  
Type II. Distribution  
(24 hr. Duration Storm)

Executed: 06-08-1995 14:15:41  
Watershed file: --> C:\PONDPACK\ABCELLS .MOP  
Hydrograph file: --> C:\PONDPACK\AB100YR.HYD

A&B Cells Only, C&D Cells Not Developed

Composite Hydrograph Summary (cfs)

Subarea Description	11.0 hr	11.3 hr	11.6 hr	11.9 hr	12.0 hr	12.1 hr	12.2 hr	12.3 hr	12.4 hr
Ash Pile Top	3	4	6	19	37	71	107	107	72
Pile sides/base	3	4	5	24	46	85	92	55	29
Total (cfs)	6	8	11	43	83	156	199	162	101

Subarea Description	12.5 hr	12.6 hr	12.7 hr	12.8 hr	13.0 hr	13.2 hr	13.4 hr	13.6 hr	13.8 hr
Ash Pile Top	45	31	23	18	13	10	9	8	7
Pile sides/base	19	15	12	10	8	7	6	6	5
Total (cfs)	64	46	35	28	21	17	15	14	12

Subarea Description	14.0 hr	14.3 hr	14.6 hr	15.0 hr	15.5 hr	16.0 hr	16.5 hr	17.0 hr	17.5 hr
Ash Pile Top	7	6	5	5	4	4	3	3	3
Pile sides/base	5	4	4	3	3	3	2	2	2
Total (cfs)	12	10	9	8	7	7	5	5	5

Subarea Description	18.0 hr	19.0 hr	20.0 hr	22.0 hr	26.0 hr
Ash Pile Top	3	3	2	2	0
Pile sides/base	2	2	1	1	0
TOTAL (cfs)	5	5	3	3	0

TABULAR HYDROGRAPH METHOD MULTIPLE RUN OPTIONS { .MOP }				
ABCELLS <-- This File .WSD File -->				
Note: Don't input .WSD file if CN & Tc/Tt files are entered below titles.				
Title: A&B Cells Only, C&D Cells Not Developed				
ABCELLS <-- .RCN File		Tc File: ABCELLS .TCT	Tt File: .	
Specify TCT or TCM extension in the field after the Tc File and in the field after the Tt File.				
Return Frequency (years):	2	25	50	100
24-hr Precip. (inches):	2.75	5.00	5.50	6.3
Hydrograph Files (.HYD):	AB2YR	AB25YR	AB50YR	AB100YR
SCS Distribution Type? II				
Interpolate Ia/P (y/n)? Y				
OUTPUT OPTIONS				
* Input Data	* Peaks	* Hydrograph Summary	Hydrographs	

<Esc> Exit

<F5> Compute

[illegible]

SURFACE DESCRIPTION	AREA (acres)	CN
Fly/bottom ash, not vegetated	22.00	85
COMPOSITE AREA --->	22.00	85.0 ( 85 )

SURFACE DESCRIPTION	AREA (acres)	CN
Ash pile slopes, topsoil & veg.	5.50	85
Haul Roads & Drainage Ditches	5.50	92
Runoff pond	3.00	100
COMPOSITE AREA --->	14.00	91.0

CN+TC 3/6

Quick TR-55 Ver.5.46 S/N:  
Executed: 14:03:59 06-08-1995

RUNOFF CURVE NUMBER SUMMARY

.....

Subarea Description -----	Area (acres) -----	CN (weighted) -----
Ash Pile Top	22.00	85
Pile sides/base	14.00	91

CN+TC 4/6

Quick TR-55 Ver.5.46 S/N:  
Executed: 14:52:01 06-08-1995 c:\pondpack\ABCELLS.TCT

SUMMARY SHEET FOR Tc or Tt COMPUTATIONS  
(Solved for Time using TR-55 Methods)

Subarea descr.	Tc or Tt	Time (hrs)
Top of Pile	Tc	0.33
Pile Sides/Botm	Tc	0.20

Tc COMPUTATIONS FOR: Top of Pile

SHEET FLOW (Applicable to Tc only)

Segment ID		Top
Surface description		Fly/botm ash
Manning's roughness coeff., n		0.0230
Flow length, L (total < or = 300)	ft	300.0
Two-yr 24-hr rainfall, P2	in	2.750
Land slope, s	ft/ft	0.0100

$$T = \frac{.007 * (n * L)}{0.5 * s} \quad \text{hrs} \quad 0.12 = 0.12$$

SHALLOW CONCENTRATED FLOW

Segment ID		Top
Surface (paved or unpaved)?		Unpaved
Flow length, L	ft	1000.0
Watercourse slope, s	ft/ft	0.0100

$$\text{Avg. V} = \text{Csf} * s \quad \text{ft/s} \quad 1.6135$$

where: Unpaved Csf = 16.1345  
 Paved Csf = 20.3282

$$T = L / (3600 * V) \quad \text{hrs} \quad 0.17 = 0.17$$

CHANNEL FLOW

Segment ID		Bot Dit
Cross Sectional Flow Area, a	sq.ft	10.50
Wetted perimeter, Pw	ft	10.70
Hydraulic radius, r = a/Pw	ft	0.981
Channel slope, s	ft/ft	0.0040
Manning's roughness coeff., n		0.0130

$$V = \frac{1.49 * r^{2/3} * s^{1/2}}{n} \quad \text{ft/s} \quad 7.1583$$

Flow length, L ft 900

$$T = L / (3600 * V) \quad \text{hrs} \quad 0.03 = 0.03$$

.....  
 TOTAL TIME (hrs) 0.33

CN+TC 6/6

Quick TR-55 Ver.5.46 S/N:  
 Executed: 14:52:01 06-08-1995 c:\pondpack\ABCELLS.TCT

Tc COMPUTATIONS FOR: Pile Sides/Botm

SHEET FLOW (Applicable to Tc only)

Segment ID	Sides		
Surface description	Topsoil& Veg		
Manning's roughness coeff., n	0.2400		
Flow length, L (total < or = 300)	ft	75.0	
Two-yr 24-hr rainfall, P2	in	2.750	
Land slope, s	ft/ft	0.3300	
		0.8	
$T = \frac{.007 * (n * L)}{0.5 * P2 * s}$		hrs	0.07 = 0.07

SHALLOW CONCENTRATED FLOW

Segment ID			
Surface (paved or unpaved)?			
Flow length, L	ft	0.0	
Watercourse slope, s	ft/ft	0.0000	
		0.5	
Avg.V = Csf * (s)	ft/s	0.0000	
where: Unpaved Csf = 16.1345			
Paved Csf = 20.3282			
$T = L / (3600 * V)$		hrs	0.00 = 0.00

CHANNEL FLOW

Segment ID		Bot Dit
Cross Sectional Flow Area, a	sq.ft	8.00
Wetted perimeter, Pw	ft	10.47
Hydraulic radius, r = a/Pw	ft	0.764
Channel slope, s	ft/ft	0.0029
Manning's roughness coeff., n		0.0230

$V = \frac{1.49 * r^{2/3} * s^{1/2}}{n}$		ft/s	2.9158
--	--	------	--------

Flow length, L	ft	1450
----------------	----	------

$T = L / (3600 * V)$		hrs	0.14 = 0.14
----------------------	--	-----	-------------

.....  
 TOTAL TIME (hrs) 0.20



## DETENTION POND RATING TABLE (.PND)

TRAP16 — Pond File 522.00 — W.S. Elev. TRAP16 — Output File ||

Titles: Leachate/Runoff Basin Overflow

Trapezoidal Weir 16 ft wide with 2:1 side slopes

No.	Elevation (ft)	Outflow (cfs)	Storage (acre-ft)	No.	Elevation (ft)	Outflow (cfs)	Storage (acre-ft)
1	522.00	0.0	9.90185	12			
2	522.25	6.2	10.57635	13			
3	522.50	18.0	11.29659	14			
4	522.75	33.7	12.06408	15			
5	523.00	52.9	12.88032	16			
6	523.25	75.5	13.74681	17			
7	523.50	101.2	14.66505	18			
8	523.75	130.0	15.63655	19			
9	524.00	161.9	16.66281	20			
10				21			
11				22			

Esc → Exit F1 → Insert Line Ctrl-X → Delete Line PgDn → Page Ahead

## DETENTION POND RATING TABLE (.PND)

PIPERISR — Pond File 522.00 — W.S. Elev. PIPERISR — Output File ||

Titles: Existing 48" diameter CMP riser overflow

Ash Area No. 3 L/R Basin

No.	Elevation (ft)	Outflow (cfs)	Storage (acre-ft)	No.	Elevation (ft)	Outflow (cfs)	Storage (acre-ft)
1	522.00	0.0	9.90185	12			
2	522.25	5.2	10.57635	13			
3	522.50	14.8	11.29659	14			
4	522.75	27.2	12.06408	15			
5	523.00	41.8	12.88032	16			
6	523.25	57.3	13.74681	17			
7	523.50	69.4	14.66505	18			
8	523.75	80.0	15.63655	19			
9	524.00	85.6	16.66281	20			
10				21			
11				22			

Esc → Exit F1 → Insert Line Ctrl-X → Delete Line PgDn → Page Ahead

## DETENTION POND RATING TABLE (.PND)

PUMPS-ON — Pond File 517.00 — W.S. Elev. PUMPS-ON — Output File ||

Titles: One 2700 GPM Pump on at el 517.00  
 2nd 2700 GPM pump on at el 520.00

No.	Elevation (ft)	Outflow (cfs)	Storage (acre-ft)	No.	Elevation (ft)	Outflow (cfs)	Storage (acre-ft)
1	517.00	6.0	0.5774	12	520.66	6.0	6.68784
2	517.33	6.0	0.98907	13	521.00	8.4	7.43815
3	517.67	6.0	1.42311	14	521.33	10.0	8.22134
4	518.00	6.0	1.88012	15	521.66	10.0	9.038
5	518.33	6.0	2.36425	16	522.00	10.0	9.8888
6	518.67	6.0	2.88026	17	522.33	19.4	10.79609
7	519.00	6.0	3.42907	18	522.66	37.7	11.78537
8	519.33	6.0	4.0117	19	522.99	62.4	12.86021
9	519.66	6.0	4.62914	20	523.33	93.1	14.02414
10	520.00	6.0	5.28242	21	523.66	129.3	15.28048
11	520.33	6.0	5.96945	22	523.99	171.0	16.63323

Esc → Exit F1 → Insert Line Ctrl-X → Delete Line PgDn → Page Ahead

## DETENTION POND VOLUMES {.VOL}

This File → POND-DIT

Scale (ft/in) → 30

Screen No. 1

Titles: Leachate/Runoff Basin Storage Capacity  
 Ponding Behind Inlet Culvert Included in Capacity

	Elevation (ft)	Planimeter (sq.in.)	Area (acres)	(acres) $A1+A2+\sqrt{A1*A2}$	Volume (acre-ft)	ΣVolume (acre-ft)
	516.5	53.58	1.11	0.00	0.00	0.00
	518.0	68.13	1.41	3.76	1.88	1.88
	520.0	97.65	2.02	5.11	3.41	5.29
	522.0	126.25	2.61	6.92	4.61	9.90
	524.0	204.08	4.22	10.14	6.76	16.66

Esc → Exit to Menu

PgUp → Screen Back

F1 → Insert Line

PgDn → Screen Ahead

Ctrl-X → Delete Line

Ctrl-P → Print Data

OUTLETS 4/6

Outlet Structure File: TRAP16WR.STR

POND-2 Version: 5.17

S/N:

Date Executed:

Time Executed:

\*\*\*\*\*

Leachate/Runoff Basin Overflow  
Trapezoidal Weir 16 ft wide with 2:1 side slopes

\*\*\*\*\*

Outflow Rating Table for Structure #1  
WEIR-XY Weir - Defined by X, Y Coordinates

\*\*\*\*\* INLET CONTROL ASSUMED \*\*\*\*\*

Elevation (ft)	Q (cfs)	Computation	Messages
522.00	0.0	E = Y min= 522	
522.25	6.2	W(ft)=17.0	Max. D(ft)=.25
522.50	18.0	W(ft)=18.0	Max. D(ft)=.5
522.75	33.7	W(ft)=19.0	Max. D(ft)=.750
523.00	52.9	W(ft)=20.0	Max. D(ft)=1.0
523.25	75.5	W(ft)=21.0	Max. D(ft)=1.25
523.50	101.2	W(ft)=22.0	Max. D(ft)=1.5
523.75	130.0	W(ft)=23.0	Max. D(ft)=1.75
524.00	161.9	W(ft)=24.0	Max. D(ft)=2.0

OUTLETS 5,

Outlet Structure File: PIPERISR.STR

POND-2 Version: 5.17

S/N:

Date Executed:

Time Executed:

\*\*\*\*\*  
Existing 48" diameter CMP riser overflow  
Ash Area No. 3 L/R Basin

\*\*\*\*\*

>>>>> Structure No. 1 <<<<<<  
(Input Data)

STAND PIPE

Stand Pipe with weir or orifice flow

E1 elev.(ft)?	522.00
E2 elev.(ft)?	524.01
Crest elev.(ft)?	522.00
Diameter (ft)?	4
Weir coefficient?	3.33
Orifice coefficient?	0.6
Start transition elev.(ft) @ ?	
Transition height (ft)?	0.5

Outlet Structure File: PIPERISR.STR

POND-2 Version: 5.17

S/N:

Date Executed:

Time Executed:

\*\*\*\*\*  
 Existing 48" diameter CMP riser overflow  
 Ash Area No. 3 L/R Basin

\*\*\*\*\*

Outflow Rating Table for Structure #1  
 STAND PIPE Stand Pipe with weir or orifice flow

\*\*\*\*\* INLET CONTROL ASSUMED \*\*\*\*\*

Elevation (ft)	Q (cfs)	Computation	Messages
522.00	0.0	Weir:	H =0.0
522.25	5.2	Weir:	H =.25
522.50	14.8	Weir:	H =.5
522.75	27.2	Weir:	H =.750
523.00	41.8	Weir:	H =1.0
523.25	57.3	Transition:	H =1.25
523.50	69.4	Transition:	H =1.5
523.75	80.0	Orifice:	H =1.75
524.00	85.6	Orifice:	H =2.0

Weir  $C_w = 3.33$  Weir length = 12.56637 ft

Orifice  $C_o = .6$  Orifice area = 12.56637 sq.ft.

$Q$  (cfs) =  $(C_w * L * H^{1.5})$  or  $(C_o * A * \text{sqr}(2*g*H))$

Transition interpolated between elev. 523.1959 and 523.6959 ft

Weir equation = Orifice equation @ elev.= 523.4459 ft



## **Stream Enclosure Design Calculations**



Dept. \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEETER No. 460230Date 19Designed by SEM

PROJECT \_\_\_\_\_

Sht. No. 1 of \_\_\_\_\_

Approved by \_\_\_\_\_

stream enclosuredesign stream enclosure  
for upstream runoff100 yr flood per 105.201  
Dam Safety & Waterway Maint.  
S.C.S. method

tributary areas

		C <sub>n</sub>	slope
A1	45	83	2.2
A2	28	71	2.5
A6	22	71	1.9

$$C_{n\text{ wtd}} = 77$$

$$\text{avg. slope} = 2.3$$

$$\Sigma 95$$

100 yr 24 hr storm  $i = 6.3$  inches  
U.S. Weather BureauHdbk of Applied Hydrology  
Fig 9-57 p 9-56

$$Q_{\text{med}} = 230 + .4(90) = 266$$

$$Q_{\text{flat}} = 135 + .4(70) = 163$$

$$Q_{2.3} = 220 \text{ cfs}$$

Dept. \_\_\_\_\_

PENNSYLVANIA POWER & LIGHT COMPANY  
CALCULATION SHEET

ER No. \_\_\_\_\_

Date \_\_\_\_\_ 19\_\_\_\_

Designed by SEH

PROJECT \_\_\_\_\_

Sht. No. 2 of \_\_\_\_\_

Approved by \_\_\_\_\_

stream enclosureStream enclosure

$$d_c = 3.2' \quad Q = 115 \text{ cfs} \quad \text{dia} = 48''$$

$$\text{slope} = \frac{521.5 - 516.0}{1630} = 0.0034 \quad \eta = 0.009$$

$$Q_{\text{full}} = \frac{1.49}{\eta} A R^{2/3} S^{1/2}$$

$$= \frac{1.49}{.009} (12.56) (1)^{2/3} (.0034)^{1/2}$$

$$= 121 \text{ cfs}$$

$$Q_{115} = \frac{1.49}{.009} 10.78 (1.22)^{2/3} (S^{1/2})$$

$$S = \left[ .0645 / 1.140 \right]^2 = 0.0032 \quad \text{critical slope}$$

$$\eta = 0.009 \sqrt{\frac{1630}{500}} = 0.016 \quad \eta = 0.012 \quad H = 4.6 \quad H_{0.16} = 7.2$$